

TECHNICAL CHARACTERISTICS

SACE Tmax XT

Low voltage molded case circuit-breakers



Break new ground

- Data and connectivity
- Ease of use and installation
- Performance and protection
- Safety and reliability

SACE Tmax XT

The complete offering

OVERALL
DIMENSIONS

WIRING DIAGRAMS

Installation

Installation environment

- 1/2** Temperature
- 1/2** Environmental conditions
- 1/2** Shocks and vibrations
- 1/2** Electromagnetic compatibility
- 1/3** Degrees of protection
- 1/3** Installation position

Temperature performance

- 1/4** Circuit-breakers with thermal-magnetic trip units
- 1/6** Circuit-breaker with magnetic only or electronic trip units and switch-disconnectors
- 1/8** Power losses

Insulation distances

- 1/10** Clearances for installation in metallic cubicles
- 1/12** Alternating Current (AC) application
- 1/13** Direct Current (DC) application
- 1/14** Minimum clearance between two side by side circuit-breakers
- 1/16** Minimum clearance between two superimposed circuit-breakers
- 1/17** The first insulated anchor

Special applications

- 1/19** Use of direct current apparatus

Characteristic curves

- 1/21** Example of curves reading
- 1/24** Trip curves with thermal-magnetic trip unit
- 1/30** Trip curves with electronic trip unit Ekip Dip
- 1/44** Trip curves with electronic trip unit Ekip Touch and Hi-Touch
- 1/54** Specific let-through energy curves
- 1/64** Limiting curves

Installation environment

Temperature

The Tmax XT circuit-breakers can be used in environmental conditions where the ambient air temperature varies between -25°C and +70°C, and can be stored at temperatures between -40 °C and +70 °C. Circuit-breakers fitted with thermomagnetic trip units have their thermal element set for a reference temperature. For temperatures other than the reference, a trip threshold variation must be taken into account. Electronic trip units do not undergo any variations in performance as the temperature varies, but, in the case of temperatures exceeding +40°C, the maximum setting for protection L (protection against overloads) must be reduced, as indicated in the derating graph, to take into account the heating phenomena which occur in the copper parts of the circuit-breaker which the phase current passes through. For temperatures above +70°C the circuit-breaker performances are not guaranteed.

Environmental conditions

The Tmax XT circuit-breakers are designed to operate in environments with a pollution degree of 3 according to the IEC 60947-2 Standard classification.

Altitude

Up to an altitude of 2000m, the Tmax XT circuit-breakers do not undergo any alteration in their rated performances. As the altitude increases, the atmospheric properties are altered in terms of composition, dielectric resistance, cooling capacity and pressure. Therefore, some performance aspects of the circuit-breaker (e.g. the maximum rated operating voltage and the rated uninterrupted current) undergo derating.

Altitude	2000m	3000m	4000m	5000m
Rated service voltage, Ue	[V] 690	621	540	470
Rated uninterrupted current	% 100	98	93	90

Shocks and vibrations

The Tmax XT circuit-breakers are unaffected by vibrations generated mechanically and due to electromagnetic effects, in compliance with the IEC 60068-2-6 Standards and the regulations of the major shipping registers including:


- RINA
- Det Norske Veritas
- Bureau Veritas
- Lloyd's Register of Shipping
- Germanischer Lloyd
- ABS
- Russian Maritime Register of Shipping
- Nippon Kaiji Kyokai.

The Tmax XT circuit-breakers are also tested according to the IEC 60068-2-27 Standard to resist shocks up to 15g for 11 ms.

Electromagnetic compatibility

Protection is guaranteed in the presence of interference caused by electronic apparatus, atmospheric disturbances or electrical discharges by using the electronic trip units and the electronic residual current releases. No interference with other electronic apparatus near the place of installation is generated either. This is in compliance with the IEC 60947-2 Annex B + Annex F Standards and European Directive No. 2014/30/EC regarding EMC - electromagnetic compatibility.

Degrees of protection




The IP degree of the circuit-breaker can vary depending on the area considered and on the presence of accessories such as a motor or terminal cover.

The following table indicates the degrees of protection guaranteed by Tmax XT circuit-breakers according to the prescriptions of the IEC 60529 Standard, in the different configurations. Furthermore, special kits are available to achieve IP54 with the MOE or RHD installed on the XT5, XT6 and XT7.

	With front	Without front	With FLD	With RHD	With RHE	Motor operator MOD, MOE or MOE-E devices	Residual current devices					
A	IP40	IP20	IP40 ⁽¹⁾	IP40 ⁽¹⁾	IP40 ⁽¹⁾⁽²⁾	IP30	IP40					
(1) XT5 W - XT6 W: IP30												
(2) XT5-XT6-XT7: IP65												
<hr/>												
Without TC		With HTC		With LTC								
B	IP20		IP40		IP40							
C	NC		IP40		IP30							
<hr/>												
Protection kits for	RHE	RHD		MOE								
XT1 , XT2, XT3,XT4	IP54	-		-								
XT5, XT6, XT7	-	IP54		IP54								
<hr/>												
Residual current RCQ020				Automatic Transfer Switch ATS021, ATS022								
On front	IP41		IP40									

Installation position



It is possible to mount circuit-breakers in the fixed, plug-in or withdrawable version in horizontal, vertical or lying down positions without any derating of the rated characteristics.

Temperature performance

Circuit-breakers with thermal-magnetic trip units

The circuit-breakers fitted with thermal-magnetic trip units have the thermal element set for a reference temperature of +40°C. With the same setting, for temperatures other than +40°C there is a variation in the thermal trip threshold as indicated in the tables below.

XT1

Ambient T (°C)	10	20	30	40	45	50	60	70
In [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]
16	13	18	12	18	11.9	17	11.2	16
20	16	23	15	22	14.7	21	14	20
25	20	29	19	28	18.2	26	17.5	25
32	26	37	25	35	23.8	34	22.4	32
40	32	46	31	44	29.4	42	28	40
50	40	58	39	55	37.1	53	35	50
63	51	72	49	69	46.2	66	44.1	63
80	64	92	62	88	58.8	84	56	80
100	81	115	77	110	73.5	105	70	100
125	101	144	96	138	91.7	131	87.5	125
160	129	184	123	176	117.6	168	112	160

XT2 with thermal-magnetic trip units

Ambient T (°C)	10	20	30	40	45	50	60	70
In [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]
1.6	1.3	1.8	1.2	1.8	1.2	1.7	1.1	1.6
2	1.6	2.3	1.5	2.2	1.5	2.2	1.4	2.0
2.5	2.0	2.9	1.9	2.8	1.8	2.6	1.8	2.5
3.2	2.5	3.6	2.5	3.5	2.5	3.5	2.0	3.2
4	3.2	4.6	3.1	4.4	2.9	4.2	2.8	4.0
5	4	5.7	3.9	5.5	3.7	5.3	3.5	5
6.3	5.0	7.2	4.9	6.9	4.6	6.6	4.4	6.3
8	6.4	9.2	6.2	8.8	5.9	8.4	5.6	8.0
10	8.1	11.5	7.7	11.0	7.4	10.5	7.0	10.0
12.5	10.1	14.4	9.7	13.8	9.2	13.2	8.8	12.5
16	13	18.0	12.0	18.0	11.9	17.0	11.2	16.0
20	16	23.0	15.4	22.0	14.7	21.0	14.0	20.0
25	20	29.0	19.6	28.0	18.2	26.0	17.5	25.0
32	26	37.0	24.5	35.0	23.8	34.0	22.4	32.0
40	32	46.0	30.8	44.0	29.4	42.0	28.0	40.0
50	40	57.0	38.5	55.0	37.1	53.0	35.0	50.0
63	50	72.0	48.3	69.0	46.2	66.0	44.1	63.0
80	64	92.0	61.6	88.0	58.8	84.0	56.0	80.0
100	81	115.0	77.0	110.0	73.5	105.0	70.0	100.0
125	101	144.0	96.6	138.0	92.4	132.0	87.5	125.0
160	129	184.0	123.0	178.0	117.6	168.0	112.0	160.0

XT3

Ambient T (°C)	10	20	30	40	45	50	60	70						
In [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]	MIN [A]	MAX [A]
63	51	72	49	69	46	66	44	63	43	61	41	59	39	55
80	64	92	62	88	59	84	56	80	54	77	53	75	48	69
100	80	115	77	110	74	105	70	100	68	97	65	93	61	87
125	101	144	96	138	92	132	88	125	85	121	81	116	76	108
160	129	184	123	176	118	168	112	160	108	155	104	149	97	139
200	161	230	154	220	148	211	140	200	136	194	130	186	121	173
250	201	287	193	278	184	263	175	250	169	242	163	233	151	216

XT4 with thermal-magnetic trip units

Ambient T (°C)	10	20	30	40	45	50	60	70
In [A]	MIN[A]	MAX[A]	MIN[A]	MAX[A]	MIN[A]	MAX[A]	MIN[A]	MAX[A]
16	13	19	13	18	12	17	11	16
20	19	27	17	24	16	23	14	20
25	21	30	20	28	19	27	18	25
32	26	43	24	39	25	36	22	32
40	33	48	32	45	30	43	28	40
50	37	62	35	58	38	54	35	50
63	53	75	50	71	47	67	44	63
80	59	98	55	92	60	86	56	80
100	83	118	79	113	74	106	70	100
125	102	145	100	140	94	134	88	125
160	130	185	123	176	118	168	112	160
200	161	230	154	220	147	210	140	200
225	188	269	179	255	168	241	158	225
250	200	285	193	275	183	262	175	250

XT5 TMA/TMG

Ambient T (°C)	10	20	30	40	45	50	60	70
In [A]	MIN[A]	MAX[A]	MIN[A]	MAX[A]	MIN[A]	MAX[A]	MIN[A]	MAX[A]
320	285	360	245	345	235	335	225	320
400	370	465	315	450	310	420	280	400
500	485	605	400	570	375	535	350	500
630	540	675	460	660	450	645	440	630

XT6 TMA

Ambient T (°C)	10	20	30	40	45	50	60	70
In [A]	MIN[A]	MAX[A]	MIN[A]	MAX[A]	MIN[A]	MAX[A]	MIN[A]	MAX[A]
630	560	700	470	670	450	645	440	630
800	770	960	635	910	600	860	560	800

Temperature performance

Circuit-breaker with magnetic only or electronic trip units and switch-disconnectors

The electronic overcurrent trip units do not undergo any variations in performance as the temperature varies. However, even though heating does not affect the trip thresholds of the electronic trip units, in the case of temperatures exceeding +40°C it is advisable to reduce the maximum L (protection against overloads) setting to protect the copper parts of the circuit-breaker against high temperatures.

The same considerations can be made for the switch-disconnectors and magnetic only circuit-breakers. The table below shows the maximum value at which the threshold of I₁ of the overcurrent protection (L) must be set according to the ambient temperature and for the type of terminals used.

				40°C	45°C	50°C	55°C	60°C	65°C	70°C
				I _{max} [A]						
XT1	F	M-SD	F-EF-ES-FCCu-R	160	160	160	153	140		
	P	M-SD	EF-HR/VR	125	117	110	108	100		
XT2	F	M-ELT	F-FCCu	160	160	160	160	145		
	P/W	M-ELT	EF-HR/VR	160	160	160	160	148		
XT3	F	M-SD	F-FCCu	250	250	250	228	204		
	P	M-SD	EF-HR/VR	250	222	196	196	170		
XT4	F	M-ELT-SD	F-FCCu	250	250	250	238	213		
	P/W	M-ELT-SD	EF-HR/VR	250	231	211	211	190		
XT5 400	F	M-ELT-SD	F	400	400	400	383	365	346	
			VR, ES, EF	400	400	400	400	381	362	
			FC CuAl	400	400	400	383	365	346	
			HR	400	400	400	383	365	346	
	P/W	M-ELT-SD	VR, ES, EF	400	385	370	355	338	321	302
			FC CuAl	400	385	370	355	338	321	302
			HR	400	385	370	355	338	321	302
XT5 630	F	M-ELT-SD	F	630	630	630	630	590	550	505
			VR, ES, EF	630	630	630	630	601	570	537
			FC CuAl	630	630	630	630	601	570	537
			HR	630	630	630	630	590	550	505
	P/W	M-ELT-SD	VR, ES, EF	600	578	555	532	507	481	454
			FC CuAl	600	578	555	532	507	481	454
			HR	600	565	530	507	484	457	430
XT6 800	F	ELT-SD	F-ES-EF-FC CuAl	800	800	800	780	760	740	720
			VR	800	800	800	800	780	760	
			HR	800	800	800	760	720	680	640
	W	ELT-SD	ES-EF-FC CuAl	800	780	760	740	720	680	640
			VR	800	800	800	780	760	740	720
			HR	800	780	760	740	720	680	640
XT6 1000¹⁾	F	ELT-SD	F-EF-FC CuAl	1000	980	960	918.5	877	830.5	784
			ES	1000	950	900	860	820	770	720
			VR	1000	1000	1000	956.5	913	865	817
			HR	1000	963	926	885.5	845	800.5	756

(1) XT6 1000 is supplied by default with EF connection terminals

				40°C	45°C	50°C	55°C	60°C	65°C	70°C
				I _{max} [A]						
XT7 800A	F	ELT	F	800	800	800	800	800	750	700
			VR, ES, FCCuAI	800	800	800	800	800	778	755
			HR, EF	800	800	800	800	800	750	700
	W	ELT	EF, ES	800	800	800	766	730	693	653
			HR, SHR	800	800	800	800	800	750	700
			VR, Rear FCCuAI	800	800	800	800	800	759	716
XT7 1000A	F	ELT-SD	F	1000	1000	1000	971	942	885	827
			VR, ES, FCCuAI	1000	1000	1000	1000	949	885	894
			HR, EF	1000	1000	1000	971	942	885	827
	W	ELT-SD	EF, ES	1000	1000	961	920	877	832	784
			HR, SHR	1000	1000	1000	971	942	885	827
			VR, Rear FCCuAI	1000	1000	1000	1000	953	905	853
XT7 1250A	F	ELT-SD	F with 2x40x10	1250	1250	1250	1184	1118	1049	980
			F with 2x50x10	1250	1250	1250	1240	1182	1122	1057
			VR, ES, FCCuAI	1250	1250	1250	1250	1192	1131	1066
	W	ELT-SD	HR, EF	1250	1250	1250	1184	1118	1049	980
			EF, ES	1250	1205	1157	1108	1056	1002	945
			HR, SHR	1250	1250	1250	1184	1118	1049	980
XT7 1600A	F	ELT-SD	VR, Rear FCCuAI	1250	1250	1250	1250	1192	1131	1066
			F with 2x50x10	1400	1350	1296	1240	1183	1122	1058
			F with 3x50x10	1600	1541	1481	1417	1352	1281	1209
	W	ELT-SD	VR, ES, FCCuAI	1600	1600	1537	1470	1403	1329	1255
			HR, EF	1600	1541	1481	1417	1352	1281	1209
			EF, ES	1400	1350	1296	1240	1183	1122	1058
			HR, SHR	1600	1541	1481	1417	1352	1281	1209
			VR, Rear FCCuAI	1600	1600	1537	1470	1403	1329	1255

Temperature performance

Power losses

To ensure service continuity of the plants, careful assessment of how to keep temperatures within acceptable levels is necessary to guarantee operation of all devices (e.g. by using forced ventilation in switchboards and installation rooms).

The table below shows the dissipated power values per single pole at the rated current I_n for each circuit-breaker used. The total maximum dissipated power for a circuit-breaker used at 50/60Hz is equal to the power per single pole multiplied by the number of poles.

Power [W/pole]	I_n [A]	XT1		XT2		XT3		XT4		XT5		XT6	
		F	P	F	P/W	F	P	F	P/W	F	P/W	F	W
Thermomagnetic	1.6			2.00	2.40								
or magnetic only	2			2.40	2.80								
trip unit:	2.5			2.50	2.80								
TMD	3.2			2.80	3.20								
TMA	4			2.50	2.80								
TMG	6.3			3.30	3.90								
MF	8			2.60	3.00								
	10			2.90	3.40			2.00	2.20				
	12.5			1.00	1.20			2.30	2.40				
	16	1.50	1.60	1.30	1.50			2.50	2.60				
	20	1.80	2.00	1.60	1.90			2.60	2.70				
	25	2.00	2.80	2.00	2.5			2.70	2.80				
	32	2.10	3.20	2.60	3.00			4.40	4.50				
	40	2.60	4.60	3.70	4.40			4.50	4.70				
	50	3.70	5.00	4.10	4.70			4.70	4.90				
	63	4.30	6.00	4.80	5.70	4.30	5.10	5.30	5.70				
	80	4.80	7.20	5.80	6.80	4.80	5.80	5.50	6.10				
	100	7.00	10.00	8.10	9.50	5.60	6.80	6.20	7.20				
	125	10.70	14.70	11.40	14.00	6.60	7.90	7.40	9.00				
	160	15.00		16.10	19.00	7.90	9.50	8.90	10.80				
	200					13.20	15.80	11.90	14.90				
	250					17.80	21.40	16.40	21.10				
	320									16.9	23		
	400									24.1	33.6		
	500									33.5	45.8		
	630									47.8	67.3	34.4	42.5
	800										54.2	67.7	
Electronic trip unit:	10			0.10	0.10								
Ekip Dip	25			0.80	0.90								
Ekip Touch	40					0.60	0.70						
	63			1.70	2.10			1.40	1.80				
	100			4.20	5.20			3.50	4.50				
	160			10.80	13.40			8.90	11.50				
	250					16.40	22.70	8	11.7				
	320									11.6	17.7		
	400									19	27.6		
	500									28.3	40.6		
	630									45	64.5	33.2	41.5
	800										53.4	66.7	
	1000										83.5		

Power [W/pole]	In [A]	XT7- XT7 M	
		F	w
Ekip Dip	800	24	35
Ekip Touch	1000	37	55
	1250	57	86
	1600	94	141

Power losses gives indication of the heat generated under specified conditions. Measurement of power losses are performed on new samples in free air (according to Annex G of IEC).

The measurement of resistance cannot be directly related to the power loss of the device and is not enough to ascertain the quality of the contacts.

Insulation distances

Clearances for installation in metallic cubicles

This section provides the compliance clearances for the installation of the circuit-breaker inside a metal cubicle.

The cubicle is the reference for the metallic parts of the switchgear assembly adjacent to the circuit-breaker and is used as a reference to define the clearances to be observed to permit the free evacuation of ionized gases and metal vapors and to prevent the ignition of adjacent parts. The clearances refer to the tests carried out in compliance with the IEC 60947-2 Standard.

The installation modality in relation to the type of circuit-breaker and the compulsory protections that must be used depending on the connection terminals is summarized in the tables below.

For further details about installation, please see the related instructions provided with the circuit-breaker.

	LTC	HTC	HTC-ES	PB 25mm	PB 100mm	PB 200mm
XT1	F	-	R	-	S	R
	EF	-	R	-	-	S
	ES	-	-	-	-	S
	FC Cu	-	R	-	S	R
	FC CuAl 1x1.5...70	-	R	-	S	R
	FC CuAl 1x35...95	-	S	-	-	-
	FB	-	R	-	S	R
	MC	-	S	-	-	-
	R	S	-	-	-	-
XT2	F	-	R	-	S	R
	EF	-	S	-	-	S
	ES	-	-	-	-	S
	FC Cu	-	R	-	S	R
	FC CuAl 1x1...95	-	R	-	S	R
	FC CuAl 1x70...185	-	S	-	-	-
	FC CuAl 2x35...70	-	S	-	-	-
	FB	-	R	-	S	R
	MC	-	S	-	-	-
XT3	F	-	R	-	S	R
	EF	-	R	-	-	S
	ES	-	-	-	-	S
	FC Cu	-	R	-	S	R
	FC CuAl 1x35...150	-	R	-	S	R
	FC CuAl 1x95...185	-	R	-	S	R
	FC CuAl 2x35...120	-	S	-	-	-
	FB	-	R	-	S	R
	MC	-	S	-	-	-
	R	S	-	-	-	-

	LTC ³⁾	HTC	HTC-ES	PB 25mm	PB 100mm	PB 200mm
XT4	F	-	R	-	S	R
	EF	-	S	-	-	S
	ES	-	-	-	-	S
	FC Cu	-	R	-	S	R
	FC CuAl 1x1...150	-	R	-	S	R
	FC CuAl 2x35...120	-	S	-	-	-
	FB	-	R	-	S	R
	MC	-	S	-	-	-
	R	S	-	-	-	-
XT5	F	-	R	-	S ⁽¹⁾	R
	EF	-	R	-	-	S ⁽²⁾
	ES	-	-	R	-	-
	R	S	-	-	-	-
	FC CuAl 1x35-185	-	R	-	S	R
	FC CuAl 1x120-240	-	R	-	S	R
	FC CuAl 1x185-300	-	R	-	S	R
	FC CuAl 2x70-240	-	R	-	-	S
XT6	F	R	R	-	-	R
	EF 800A	-	R	-	-	S
	EF 1000A	-	-	-	-	S
	ES	-	-	R	-	-
	R	S	-	-	-	-
	Fc CuAl 2x 120...240	R	R	-	-	R
	Fc CuAl 3x 70...185	-	S	-	-	-
	Fc CuAl 4x 70...150	-	S	-	-	-
XT7 XT7 M	F	R	R	-	-	R
	EF	-	R	-	-	S
	ES	-	-	R	-	-
	HR/VR	S	-	-	-	-
	FC CuAl 4x240	-	S	-	-	-
	FC CuAl 2x185...240	S	R	-	-	S

(1) above 500V AC

(2) PBs 50mm for W/P versions

(3) For XT5 LTC height is 25mm

Insulation distances

Alternating Current (AC) application

	No accessories			Low terminal cover (LTC)			High terminal cover (HTC)			Phase separators 25mm			Phase separators 100mm			Phase separators 200mm			
	T	D	L	T	D	L	T	D	L	T	D	L	T	D	L	T	D	L	
XT1	U < 440 V	-	-	-	25	20	20	10	5	20	0	0	20	0	0	20	0	0	20 ⁽¹⁾
	440 V < U < 500V	-	-	-	25	20	20	10	5	20	0	0	20	0	0	20	0	0	20 ⁽¹⁾
	500 V ≤ U ≤ 690V	-	-	-	25	20	20	10	5	20	0	0	20	0	0	20	0	0	20 ⁽¹⁾
XT2	U < 440 V	-	-	-	30	25	10	20	15	10	5	0	10	0	0	10	0	0	10 ⁽¹⁾
	440 V < U < 500V	-	-	-	50	45	20	40	35	20	25	20	20	0	0	20	0	0	20 ⁽¹⁾
	500 V ≤ U ≤ 690V	-	-	-	50	45	20	40	35	20	25	20	20	0	0	20	0	0	20 ⁽¹⁾
XT3	U < 440 V	-	-	-	50	20	20	45	15	20	25	0	20	0	0	20	0	0	20 ⁽¹⁾
	440 V < U < 500V	-	-	-	50	20	20	45	15	20	25	0	20	0	0	20	0	0	20 ⁽¹⁾
	500 V ≤ U ≤ 690V	-	-	-	50	20	20	45	15	20	25	0	20	0	0	20	0	0	20 ⁽¹⁾
XT4	U < 440 V	-	-	-	30	25	10	25	20	10	5	0	10	0	0	10	0	0	10 ⁽¹⁾
	440 V < U < 500V	-	-	-	50	45	20	45	40	20	25	20	20	10	5	20	0	0	20 ⁽¹⁾
	500 V ≤ U ≤ 690V ⁽³⁾	-	-	-	50	45 ⁽²⁾	20	45	40	20	25	20 ⁽²⁾	20	10	5	20	0	0	20 ⁽¹⁾
XT4X	U ≤ 690V AC	-	-	-	100	100	50	40	40	50	75	75	50	10	10	50	0	0	20 ⁽¹⁾
XT5	U ≤ 440 V AC	30	25	25	5	5	25	10	10	25	10	10	25	10	10	25	0	0	25 ⁽¹⁾
	440 V AC < U < 500V AC	30	25	25	5	5	25	10	10	25	10	10	25	10	10	25	0	0	25 ⁽¹⁾
	500 V AC ≤ U ≤ 690 V AC	-	-	-	35	20	25	40	40	25	35	20	25	10	10	25	0	0	50 ⁽¹⁾
XT6	U ≤ 440 V AC	35	20	25	35	20	25	35	20	25	-	-	-	0	0	25	0	0	25 ⁽¹⁾
	440 V AC < U < 500V AC	100	20	25	100	20	25	35	20	25	-	-	-	0	0	25	0	0	25 ⁽¹⁾
	500 V AC ≤ U ≤ 690 V AC	100	20	25	100	20	25	35	20	25	-	-	-	0	0	25	0	0	25 ⁽¹⁾
XT7	U < 440 V	50	10	20	50	10	20	5	0	5	-	-	-	0	0	20	0	0	20 ⁽¹⁾
	440 V < U < 500V	100	10	20	100	10	20	40	10	5	-	-	-	50	0	20	0	0	20 ⁽¹⁾
	500 V ≤ U ≤ 690V	100	10	20	100	10	20	40	10	5	-	-	-	50	0	20	0	0	20 ⁽¹⁾

(1) In case of ES terminals this distance has to be considered starting from terminal edge

(2) XT4V only: 50mm with LTC and 25mm with PSs 25mm


(3) XT4V only: for application at 690VAC the insulation distances to be used are the same of XT4X

Direct Current (DC) application

	No accessories			Low terminal cover (LTC)			High terminal cover (HTC)			Phase separators 25mm			Phase separators 100mm			Phase separators 200mm			
	T	D	L	T	D	L	T	D	L	T	D	L	T	D	L	T	D	L	
XT1	U ≤ 250V	-	-	25	20	20	10	5	20	0	0	20	0	0	20	0	0	20 ⁽¹⁾	
	250V < U ≤ 500V	-	-	25	20	20	10	5	20	0	0	20	0	0	20	0	0	20 ⁽¹⁾	
XT2	U ≤ 250V	-	-	50	45	50	40	35	50	25	20	50	0	0	50	0	0	50 ⁽¹⁾	
	250V < U ≤ 500V	-	-	50	45	50	40	35	50	25	20	50	0	0	50	0	0	50 ⁽¹⁾	
XT3	U ≤ 250V	-	-	50	20	20	45	15	20	25	0	20	0	0	20	0	0	20 ⁽¹⁾	
	250V < U ≤ 500V	-	-	50	20	20	45	15	20	25	0	20	0	0	20	0	0	20 ⁽¹⁾	
XT4	U ≤ 250V	-	-	30	25	20	25	20	20	5	0	20	0	0	20	0	0	20 ⁽¹⁾	
	250V < U ≤ 500V	-	-	50	45	50	45	40	50	25	20	50	10	5	50	0	0	50 ⁽¹⁾	
XT4V/X*	U ≤ 500V	-	-	50	45	50	45	40	50	25	20	50	10	5	50	0	0	50	
	500V < U ≤ 750V	-	-	100	100	50	45	40	50	75	75	50	10	5	50	0	0	50	
XT5	U ≤ 250 V DC	30	25	25	5	0	25	10	10	25	10	10	25	10	10	25	0	0	25 ⁽¹⁾
	U ≤ 500 V DC	-	-	-	40	0	25	40	40	25	40	40	25	10	10	25	0	0	25 ⁽¹⁾
	500 V DC < U ≤ 750V DC	-	-	-	40	20	25	60	60	50	60	60	50	10	10	50	0	0	50 ⁽¹⁾
XT6	U ≤ 500 V DC	35	20	25	35	20	25	35	20	25	-	-	-	0	0	25	0	0	25 ⁽¹⁾
	500 V DC < U ≤ 750V DC	100	20	25	100	20	25	35	20	25	-	-	-	0	0	25	0	0	25 ⁽¹⁾
XT7	U ≤ 500V	50	10	20	50	10	20	5	0	5	-	-	-	0	0	20	0	0	20 ⁽¹⁾
	500V < U ≤ 750V	100	10	20	100	10	20	30	10	5	-	-	-	50	0	20	0	0	20 ⁽¹⁾

* Considered only FC CuAl with PB 25mm configuration

(1) in case of ES terminals this distance has to be considered starting from the terminal edge



Insulation distances

Minimum clearance between two side by side circuit-breakers

This section gives the clearances to be observed for side by side installation of SACE Tmax XT circuit-breakers in plants with voltages up to 690V AC.

The following table show the minimum center distance between two circuit-breaker side by side. When side by side breakers are different in size, the larger reference clearance should be considered.

In case of Tmax XT1 up to XT5⁽¹⁾, the values are valid only when they have an HTC or a phase separator is inserted in the slot formed when placing the two fixed circuit-breakers side by side (see Fig.1 and Fig.2). For further details about installation, please see the related instructions provided with the circuit-breaker."

	Circuit-breaker width (mm)		Centre distance I (mm)	
	3 poles	4 poles	3 poles	4 poles
XT1	76	102	76	102
XT2	90	120	90	120
XT3	105	140	105	140
XT4	105	140	105	140
XT5	140	186	140	186
XT6	210	280	210	280
XT7	210	280	210 ⁽²⁾	280 ⁽²⁾

(1) XT5: HTC or phase separators requested for installation voltage values $U_e \geq 500V$ only

(2) for installation with F terminals only. With other connections refer to distances fixed by dimensions of back insulating plates requested




Fig. 1
Side by side XT1...
XT5⁽¹⁾ with HTC

Fig. 2
Side by side XT1...XT5⁽¹⁾
with phase separators




Fig. 1





Fig. 2

If the conditions written above are not fulfilled, SACE Tmax XT circuit-breakers can be installed side by side with a minimum clearance D as shown in the following table:

Circuit-breaker	Terminals	D [mm]
XT1-XT3 F-P	ES	35
	EF	35
	Other types of terminals	25
XT2-XT4 F-P-W	ES	120
	EF	35
	Other types of terminals	25
XT5 F-P-W	ES	120
	EF	150
	Other types of terminals	50
XT6 F-W	ES	120
	EF	150
	Other types of terminals	50
XT7 F-W	ES	150
	EF	70
	Other types of terminals	0 fixed - 70 withdrawable




Insulation distances

Minimum clearance between two superimposed circuit-breakers

This section gives the clearances H to meet for superimposed mounting of the SACE Tmax XT circuit-breakers in installations with voltages up to 690Vac. Verify that the bare bars or connection cables do not reduce the recommended clearances.

The distances given in the table refer to the maximum overall dimensions of the circuit-breakers in the different versions (F/W/P), with terminals and metallic lugs of insulated cables included, for example. When superimposed circuit-breakers are different in size, the larger reference clearance should be considered.

Circuit-breaker	H [mm]
XT1	80
XT2	100
XT3	140
XT4	150
XT5	200
XT6	180
XT7	180




In case of cables with metallic lugs, an insulating screen behind the metallic lugs (on the rear of the circuit-breaker) or high terminal covers is mandatory.

The first insulated anchor


For the Tmax XT molded-case circuit-breakers, the figure below gives an example of the maximum recommended distance (in mm) within which the first insulated anchor should be positioned according to the highest admissible peak current value of the circuit-breaker and according to the cross-sectional area of the cable.

The maximum recommended distance is also valid for busbar connections. For further information and details circuit-breaker instruction manuals should be consulted.


SACE Tmax XT1




SACE Tmax XT2



SACE Tmax XT3




SACE Tmax XT4




Insulation distances


SACE Tmax XT5



SACE Tmax XT6



SACE Tmax XT7



Special applications

Use of direct current apparatus

Variation in magnetic tripping

The thermal-magnetic trip units of the SACE Tmax XT circuit-breakers are suitable for use in direct current applications. For the protection thresholds against short-circuits, correction values (K_m) must be used, according to the type of distribution network and to the number of poles to be connected in series (the thermal threshold does not undergo any alteration).

The correction value to be used can be found in the following tables.

Connection diagrams of poles in an insulated network

Insulated network				
Un	≤250	≤500	≤750	
Protection + insulation function				
XT1	1.6		1.6	
XT2	1.5	1.5		
XT3	1.35	1.35		
XT4	1.5	1.5		1.5
XT5	1.1	1.1		1.1
XT6	1.1	1.1		1




Connection diagrams of poles in a network with one grounded polarity

Network with one grounded polarity				
Un	≤250	≤500	≤750	
Protection + insulation function				
Protection function				
XT1	1.6			
XT2	1.5	1.5	1.5	1.5
XT3	1.35	1.35	1.35	1.35
XT4	1.5	1.5	1.5	1.5
XT5	1.1	1.1		1.1
XT6	1.1	1.1		1

Note: in the considered connections, the earthed polarity is the negative one.

Special applications

Connection diagrams of poles in switch-disconnectors

Switch-disconnectors		Un	≤250	≤500	≤750
Protection + insulation function					
XT1			■		■
XT3			■	■	
XT4			■	■	
XT5			■	■	■
XT6			■	■	■
XT7			■	■	■

Coordination

Coordination between circuit-breakers

Selection of the protection system for electrical installation is fundamental both to guarantee correct economical and functional service of the whole installation and to reduce to a minimum the problems caused by abnormal service conditions or actual faults.

The coordination between the various devices dedicated to the protection of sections of installation or specific components has to be studied in order to have a protection system able to:

- detect what has happened and where, discriminating between abnormal but tolerable situations and fault situations within its zone of competence, thus avoiding unwanted trips which may cause unjustified stoppage of a properly operating part of the installation;
- act as rapidly as possible to limit the damage (destruction, accelerated ageing, etc.), thus safeguarding power supply continuity and stability.

In order to achieve these goals, it is necessary to know the operating coordination between an upstream circuit-breaker and the downstream one and choose the best combination that fits the installation specific needs.

Selectivity and back-up coordination

There are two different type of coordination between circuit-breakers.

If the priority of the installation is to assure service continuity, then selectivity is the coordination strategy. Selectivity, according to IEC 60947-1, is the coordination between the operating characteristics of two overcurrent protection devices. In the event of an overcurrent within established limits, only the circuit-breaker installed on the line affected by the fault (downstream) will trip. If the overcurrent value exceeds the selectivity limit, then also the upstream device will trip.

If the priority of the installation is to achieve economical savings of the components, then back-up is the suitable coordination. Back-up is the coordination between the operating characteristics of two overcurrent protection devices, so that the upstream protection supports the trip of the downstream protection in case of a short-circuit with a higher value than the short-circuit capacity of the downstream circuit-breaker. In this way, it is possible to optimize the breaking capacity of downstream protection devices by downsizing them.

Coordination

Selected Optimized Coordination – SOC Online tool


ABB offers a quick and easy way to find the best coordination between circuit-breakers with [SOC Online tool](#).

This tool is not limited to molded-case circuit-breakers, but it includes constantly updated coordination tables for a wide range of ABB protection devices.

Tables can be examined directly online but is also possible to download a PDF version to have a ready to use project documentation.

Step 1

Set your country/language preferences or read the help pages



Step 2

Set the

rated voltage*

Choose the upstream protection*

Choose the downstream protection*

Technology	Rated current (A)	Series	Upstream Protection										Downstream Protection									
			Icu (kA)			Icu (kA)			Icu (kA)			Icu (kA)			Icu (kA)			Icu (kA)			Icu (kA)	
T1	100	T1	100	100	100	T1	100	100	100	T1	100	100	T1	100	100	T1	100	100	T1	100	100	
T2	100	T2	100	100	100	T2	100	100	100	T2	100	100	T2	100	100	T2	100	100	T2	100	100	
T3	100	T3	100	100	100	T3	100	100	100	T3	100	100	T3	100	100	T3	100	100	T3	100	100	
T4	100	T4	100	100	100	T4	100	100	100	T4	100	100	T4	100	100	T4	100	100	T4	100	100	

* Filters can be set without a fixed sequence. If a filter has been modified, others will be kept (if allowed by the conditions).

**This is only valid for selectivity.

Table with coordination results (expressed in kA):

- **numeric value:** represents the max value of short circuit current for which the upstream device is selective (or it guarantees back-up) towards the downstream device;
- **empty cells:** means that for the relative rated currents the selectivity/back-up cannot be achieved;
- **T^{**}:** means that the upstream device assures selectivity up to the Icu value of the downstream device (Total Selectivity)

Characteristic curves

Example of curves reading

Example 1 - XT3N 250


Trip curves for distribution - (thermal magnetic trip unit)

These curves provide information about the tripping time of the thermal magnetic trip units. The red band indicates the hot trip times, that is with the breaker already loaded with its rated current once the overload has occurred.

The blue band gives the cold trip times, that is with no current flowing into the breaker before the fault.

The curves are assumed at reference air ambient temperature of 40°C and considering three phase overload with symmetrical and equilibrated currents.

Let us consider an XT3N 250 TMD In=250 A circuit-breaker. The trip time of the thermal protection varies considerably depending on the conditions when the overload occurs, i.e. whether the circuit-breakers is at the thermal regime (either cold or hot trip conditions). For example, for an overload current $3 \times I_1$, the trip time ranges from 107.9 s to 31.5 s for cold tripping and from 31.5 s to 7.0 s for hot tripping. For fault current values higher than 2500 A, the circuit-breaker trips with the instantaneous magnetic protection I_3 .




Example 2 - XT2N 160

Specific let-through energy curves

The following figure shows an example of the graph of the specific let-through energy of the XT2N 160 In=160A circuit-breaker at 220/230V. The prospective symmetrical short-circuit current is indicated on the x-axis, whereas the values of the specific let-through energy expressed in A²s are shown on the y-axis.

The circuit-breaker lets through a value of $I^2 t$ equal to $0.76 \cdot 10^6 \cdot A^2 s$ in correspondence with a short-circuit current of 20 kA.



Characteristic curves

Example of curves reading


Example 3 - XT2N 160

Limitation curves

The figure below gives the trend of the limitation curves of the XT2N 160 $I_{n}=160$ A circuit-breaker. The effective value of the prospective symmetrical short-circuit current is given on the x-axis of the graph, whereas the peak value of the short-circuit current is indicated on the y-axis.

The limiting effect can be evaluated by comparing the peak value corresponding to the prospective short-circuit current (curve A) with the peak limited value (curve B), at the same value of symmetrical short-circuit current.

For a fault current of 20 kA, the XT2N 160 circuit-breaker with a thermal magnetic trip unit $I_n = 160$ A limits the peak prospective short-circuit current to 13.5 kA at a voltage of 500 V, with a reduction of 36.5 kA in relation to the peak value of the prospective short-circuit current.





Example 4 - XT4N 250 Ekip M-LIU

Cold trip / hot trip curves

The first curve shows the time of intervention of the trip unit in case of fault under cold conditions. Each curve is related to a single operating class defined by Standard IEC 60947-4-1 (3E, 5E, 10E or 10E). The second curve, hot trip, must be read in relation to the previous one. Considering the time the circuit-breaker has remained open after the first trip (t-off on the x-axis), the t-hot/t-cold ratio can be identified on the y-axis.

Once the cold trip time has been identified on the first graph in relation to a fault current, the hot trip time can be calculated on the second graph, based on t_{off} and class of intervention. For a XT4N 250 $I_n=200A$ in the operating class 10E, given a fault current of $0.8kA$ ($4 \times I_n$), the cold trip time for intervention is 7s. If we consider a $t_{off} = 90s$, $t_{hot}/t_{cold} = 0.4$, the hot trip time results 2.8s.




Characteristic curves


Trip curves with thermal magnetic trip unit

Trip curves for distribution


XT1 160 TMD In=16...63A




XT1 160 TMD In=80...160A







XT2 160 TMA In=1.6...50A



XT2 160 TMA In=63...160A




XT2 160 TMA In=100A**XT3 250 TMD In=63...250A****XT4 250 TMA In=16...250A****XT5 400-630 TMA In=320...630A**


Characteristic curves

Trip curves with thermal magnetic trip unit

XT6 800 TMA In=630A




XT6 800 TMA In=800A




Trip curves for motor protection


XT1 125 MA $I_{n}=3.2 \dots 6.3A$




XT1 125 MA $I_{n}=16 \dots 125A$



XT2 160 MF/MA $I_{n}=1 \dots 160A$




XT3 250 MA $I_{n}=100 \dots 250A$




Characteristic curves

Trip curves with thermal magnetic trip unit

XT4 200 MA In=10...200A




XT5 400-630 MA In=320...500A




Trip curves for generator protection


XT2 160 TMG In=16...160A



XT3 250 TMG In=63...250A



XT5 400-630 TMG In=320...630A




Characteristic curves


Trip curves with electronic trip unit Ekip Dip

Trip curves for distribution


**XT2 Ekip LS/I
L-I functions**




XT2 Ekip LS/I
L-S functions




XT2 Ekip LIG
L-I functions




XT2 Ekip LIG
G function




XT2 Ekip LSI L-S-I functions




XT2 Ekip LSIG L-S-I functions



XT2 Ekip LSIG G function




XT4 Ekip LS/I L-I functions




Characteristic curves

Trip curves with electronic trip unit Ekip Dip


**XT4 Ekip LS/I
L-S functions**




**XT4 Ekip LIG
L-I functions**







**XT4 Ekip LIG
G function**



**XT4 Ekip LSI
L-S-I functions**




XT4 Ekip LSIG**L-S-I functions****XT4 Ekip LSIG****G function****XT5 Ekip Dip LS/I****L-S-I functions****XT6 Ekip Dip LS/I****L-S-I functions**

Characteristic curves

Trip curves with electronic trip unit Ekip Dip


XT5 400 Ekip Dip LIG

L-I functions




XT5 630 Ekip Dip LIG

L-I functions




XT6 Ekip Dip LIG





L-I functions



XT5-XT6 Ekip Dip LIG

G functions




XT5 Ekip Dip LSI**L-S-I functions****XT6 Ekip Dip LSI****L-S-I functions****XT5-XT6 Ekip Dip LSIG****G function****XT7 - XT7 M Ekip Dip LS/I****L-I functions**

Characteristic curves

Trip curves with electronic trip unit Ekip Dip


XT7 - XT7 M Ekip Dip LS/I

L-S functions




XT7 - XT7 M Ekip Dip LIG

L-I functions




XT7 - XT7 M Ekip Dip LIG





G function



XT7 - XT7 M Ekip Dip LSI

L-S-I functions




XT7 - XT7 M Ekip Dip LSIG**L-S-I functions****XT7 - XT7 M Ekip Dip LSIG****G function****Trip curves for motor protection****XT2 Ekip I
I function****XT4 Ekip I
I function**

Characteristic curves

Trip curves with electronic trip unit Ekip Dip


XT2 - XT4 Ekip M-LIU

L function (cold trip)




XT2 - XT4 Ekip M-LIU

(hot trip)




XT2 - XT4 Ekip M-LIU





I function



XT2 - XT4 Ekip M-LIU

U function




XT2 - XT4 Ekip M-LRIU**L function (cold trip)****XT2 - XT4 Ekip M-LRIU****U function****XT2 - XT4 Ekip M-LRIU****I function****XT2 - XT4 Ekip M-LRIU****R function**

Characteristic curves

Trip curves with electronic trip unit Ekip Dip


XT5-XT6 Ekip M Dip I

I function




XT5-XT6 Ekip M Dip LIU

(hot trip)




XT5-XT6 Ekip M Dip LIU



L function (cold trip)



XT5-XT6 Ekip M Dip LIU

I function




XT5-XT6 Ekip M Dip LIU**U function****XT7 - XT7 M Ekip M Dip I****I function**

Characteristic curves


Trip curves with electronic trip unit Ekip Dip

Trip curves for generator protection


**XT2 Ekip G-LS/I
L-I functions**




**XT2 Ekip G-LS/I
L-S functions**




**XT4 Ekip G-LS/I
L-I functions**




**XT4 Ekip G-LS/I
L-S functions**




XT5-XT6 Ekip G Dip LS/I L-S-I functions



XT7 - XT7 M Ekip G Dip LS/I L-I functions



XT7 - XT7 M Ekip G Dip LS/I L-S functions




Characteristic curves

Trip curves with electronic trip unit Ekip Touch and Hi-Touch

Trip curves for distribution


XT2

**Ekip Touch LSI • Ekip Touch LSIG • Ekip Touch Measuring LSI •
Ekip Touch Measuring LSIG • Ekip Hi-Touch LSI-
Ekip Hi-Touch LSIG • L-S-I function**




XT4

**Ekip Touch LSI • Ekip Touch LSIG • Ekip Touch Measuring LSI •
Ekip Touch Measuring LSIG • Ekip Hi-Touch LSI • Ekip Hi-Touch
LSIG • L-S-I function**




XT2

Ekip Touch LSIG • Ekip Touch Measuring LSIG • Ekip Hi-Touch LSIG • G function




XT4

Ekip Touch LSIG • Ekip Touch Measuring LSIG • Ekip Hi-Touch LSIG • G function




XT5


Ekip Touch LSI • Ekip Touch LSIG • Ekip Touch Measuring LSI • Ekip Touch Measuring LSIG • Ekip Hi-Touch LSI • Ekip Hi-Touch LSIG • L – S – I function

**XT5**


Ekip Touch LSIG • Ekip Touch Measuring LSIG • Ekip Hi-Touch LSIG • G function

**XT7 – XT7 M**

Ekip Touch LSI • Ekip Touch LSIG • Ekip Touch Measuring LSI • Ekip Touch Measuring LSIG • Ekip Hi-Touch LSI • Ekip Hi-Touch LSIG • L – S – I function

**XT7 – XT7 M**

Ekip Touch LSIG • Ekip Touch Measuring LSIG • Ekip Hi-Touch LSIG • G function




Characteristic curves

Trip curves with electronic trip unit Ekip Touch and Hi-Touch

Trip curves for distribution


XT2

Ekip Touch LSI • Ekip Touch LSIG • Ekip Touch Measuring LSI • Ekip Touch Measuring LSIG • Ekip Hi-Touch LSI • Ekip Hi-Touch LSIG • 2I function




XT4

Ekip Touch LSI • Ekip Touch LSIG • Ekip Touch Measuring LSI • Ekip Touch Measuring LSIG • Ekip Hi-Touch LSI • Ekip Hi-Touch LSIG • 2I function




XT5

Ekip Touch LSI • Ekip Touch LSIG • Ekip Touch Measuring LSI • Ekip Touch Measuring LSIG • Ekip Hi-Touch LSI • Ekip Hi-Touch LSIG • 2I function




XT7 – XT7 M

Ekip Touch LSI • Ekip Touch LSIG • Ekip Touch Measuring LSI • Ekip Touch Measuring LSIG • Ekip Hi-Touch LSI • Ekip Hi-Touch LSIG • 2I function




Trip curves for motor protection


**XT2 Ekip M Touch LRIU
L function (cold trip)**




**XT2 Ekip M Touch LRIU
(hot trip)**



**XT2 Ekip M Touch LRIU
R function - JAM**



**XT2 Ekip M Touch LRIU
R function - STALL**




Characteristic curves

Trip curves with electronic trip unit Ekip Touch and Hi-Touch


XT2 Ekip M Touch LRIU

I function




XT2 Ekip M Touch LRIU

U function




XT4 Ekip M Touch LRIU

L function (cold trip)




XT4 Ekip M Touch LRIU

(hot trip)




XT4 Ekip M Touch LRIU

R function - JAM




XT4 Ekip M Touch LRIU

R function - STALL




XT4 Ekip M Touch LRIU

I function



XT4 Ekip M Touch LRIU


U function




Characteristic curves

Trip curves with electronic trip unit Ekip Touch and Hi-Touch


XT5 Ekip M Touch LRIU
L function (cold trip)




XT5 Ekip M Touch LRIU
(hot trip)



XT5 Ekip M Touch LRIU
R function - JAM




XT5 Ekip M Touch LRIU
R function - STALL




XT5 400 Ekip M Touch LRIU

I function




XT5 Ekip M Touch LRIU

U function




XT5 630 Ekip M Touch LRIU

I function



XT7 – XT7 M Ekip M Touch LRIU


L function (cold trip)




Characteristic curves

Trip curves with electronic trip unit Ekip Touch and Hi-Touch


**XT7-XT7M Ekip M Touch LRIU
(hot trip)**




**XT7 – XT7 M Ekip M Touch LRIU
R function - JAM**




**XT7-XT7 M Ekip M Touch LRIU
R function - STALL**



**XT7 – XT7 M Ekip M Touch LRIU
I function**




XT7 – XT7 M Ekip M Touch LRIU**U function**

Characteristic curves


Trip curves with electronic trip unit Ekip Touch and Hi-Touch

Trip curves for generator protection


XT5 Ekip G Touch LSIG • Ekip G Hi-Touch LSIG
L-S-I functions




XT5 Ekip G Touch LSIG • Ekip G Hi-Touch LSIG
G function



XT7 – XT7 M Ekip G Touch LSIG • Ekip G Hi-Touch LSIG
L-S-I functions



XT7 – XT7 M Ekip G Touch LSIG • Ekip G Hi-Touch LSIG
G function




Characteristic curves


Specific let-through energy curves

240V


XT1
240V




XT2
240V



XT3
240V



XT4
240V




Characteristic curves


Specific let-through energy curves

240V


XT5
240V







XT6
240V



XT7 - XT7 M S-H-L
240V







415V

**XT1
415V****XT2
415V****XT3
415V****XT4 N-S-H-L
415V**





Characteristic curves

Specific let-through energy curves

415V

XT4 V-X
415V
Note: XT4X starting from $I_n=32A$
XT5
415V

XT6
415V

XT7 - XT7 M S-H-L
415V






440V

**XT1
440V****XT2
440V****XT3
440V****XT4 N-S-H-L
440V**





Characteristic curves

Specific let-through energy curves

440V

XT4 V-X
440V**XT5**
440V**XT6**
440V**XT7 - XT7 M S-H-L**
440V

500V


**XT1
500V****XT2
500V****XT3
500V****XT4 N-S-H-L
500V**

Characteristic curves


Specific let-through energy curves

500V


XT4 V-X
500V

Note: XT4X starting from $I_n=32\text{A}$


XT5
500V







XT6
500V



XT7 - XT7 M S-H-L
500V



690V


XT1
690V**XT2**
690V**XT3**
690V**XT4 N-S-H-L**
690V

Characteristic curves

Specific let-through energy curves


690V

XT4 V-X
690V




Note: XT4X starting from In=32A


XT5
690V



XT6 800/1000
690V



XT7 - XT7 M S-H-L
690V




Characteristic curves


Limiting curves

240V


XT1
240V




XT2
240V



XT3
240V



XT4
240V




Characteristic curves


Limiting curves

240V


XT5
240V







XT6
240V



XT7 - XT7 M S-H-L
240V







415V**XT1**
415V**XT2**
415V**XT3**
415V**XT4 N-S-H-L**
415V





Characteristic curves

Limiting curves

415V

XT4 V-X
415V
Note: XT4X starting from $I_n=32$ A
XT5
415V

XT6
415V

XT7 - XT7 M S-H-L
415V


440V


**XT1
440V****XT2
440V****XT3
440V****XT4 N-S-H-L
440V**

Characteristic curves


Limiting curves

440V


XT4 V-X
440V

Note: XT4X starting from $I_n=32\text{A}$


XT5
440V







XT6
440V



XT7 - XT7 M S-H-L
440V



500V


**XT1
500V****XT2
500V****XT3
500V****XT4 N-S-H-L
500V**

Characteristic curves

Limiting curves


500V

XT4 V-X
500V




Note: XT4X starting from $I_n=32\text{A}$


XT5
500V







XT6
500V



XT7 - XT7 M S-H-L
500V



690V


**XT1
690V****XT2
690V****XT3
690V****XT4 N-S-H-L
690V**

Characteristic curves


Limiting curves

690V


XT4 V-X
690V

Note: XT4X starting from $I_n=32\text{A}$


XT5
690V



XT6
690V



XT7 - XT7 M S-H-L
690V



Overall dimensions

Tmax XT1 – Installation

- 2/3** Installation for fixed circuit breaker
- 2/6** Terminals for fixed circuit-breaker
- 2/9** Accessories for fixed circuit-breaker
- 2/17** Installation for plug-in circuit breaker
- 2/20** Terminals for plug-in circuit-breaker
- 2/23** Accessories for plug-in circuit-breaker

Tmax XT2 – Installation

- 2/24** Installation for fixed circuit breaker
- 2/27** Terminals for fixed circuit-breaker
- 2/31** Accessories for fixed circuit-breaker
- 2/37** Installation for plug-in circuit breaker
- 2/41** Terminals for plug-in circuit-breaker
- 2/45** Accessories for plug-in circuit-breaker
- 2/49** Installation for withdrawable circuit breaker
- 2/53** Terminals for withdrawable circuit-breaker
- 2/58** Accessories for withdrawable circuit-breaker

Tmax XT3 – Installation

- 2/63** Installation for fixed circuit breaker
- 2/66** Terminals for fixed circuit-breaker
- 2/70** Accessories for fixed circuit-breaker
- 2/76** Installation for plug-in circuit breaker
- 2/79** Terminals for plug-in circuit-breaker
- 2/83** Accessories for plug-in circuit-breaker

Tmax XT4 – Installation

- 2/84** Installation for fixed circuit breaker
- 2/87** Terminals for fixed circuit-breaker
- 2/92** Accessories for fixed circuit-breaker
- 2/98** Installation for plug-in circuit breaker
- 2/102** Terminals for plug-in circuit-breaker
- 2/106** Accessories for plug-in circuit-breaker
- 2/110** Installation for withdrawable circuit breaker
- 2/114** Terminals for withdrawable circuit-breaker
- 2/119** Accessories for withdrawable circuit-breaker

Tmax XT5

- 2/124** Installation for fixed circuit-breaker
- 2/126** Terminals for fixed circuit-breaker
- 2/132** Accessories for fixed circuit-breaker
- 2/142** Installation for plug-in circuit-breaker 400A
- 2/144** Terminals for plug-in circuit-breaker 400A
- 2/147** Accessories for plug-in circuit-breaker 400A
- 2/157** Installation for plug-in circuit-breaker 630A
- 2/159** Terminals for plug-in circuit-breaker 630A
- 2/162** Accessories for plug-in circuit-breaker 630A

- 2/172** Installation for withdrawable circuit-breaker 400A
2/174 Terminals for withdrawable circuit-breaker 400A
2/179 Accessories for withdrawable circuit-breaker 400A
2/185 Installation for withdrawable circuit-breaker 630A
2/187 Terminals for withdrawable circuit-breaker 630A
2/192 Accessories for withdrawable circuit-breaker 630A

Tmax XT6 – Installation

- 2/198** Installation for fixed circuit-breaker
2/200 Terminals for fixed circuit-breaker
2/206 Accessories for fixed circuit-breaker
2/213 Installation for withdrawable circuit-breaker
2/215 Terminals for withdrawable circuit-breaker
2/216 Accessories for withdrawable circuit-breaker

Tmax XT7 – Installation


- 2/221** Installation for fixed circuit-breaker
2/222 Terminals for fixed circuit-breaker
2/226 Accessories for fixed circuit-breaker
2/228 Installation for withdrawable circuit-breaker
2/229 Terminals for withdrawable circuit-breaker
2/232 Accessories for withdrawable circuit-breaker

Tmax XT7 M – Installation

- 2/234** Installation for fixed circuit-breaker
2/235 Terminals for fixed circuit-breaker
2/239 Installation for withdrawable circuit-breaker
2/240 Terminals for withdrawable circuit-breaker

Tmax XT – Common accessories

- 2/241** Horizontal interlock XT series
2/245 Vertical interlock XT series





To access the full set of drawings in ABB Library scan the QR code or enter through the following link:
to.abb/WPBfA07x

Tmax XT1 – Installation

Installation for fixed circuit-breaker

Fixing on support sheet



- Key
 1 Overall dimensions of optional wiring ducts
 2 Phase separators 25mm



	A
With standard flange	3p - 4p 74
Without flange	3p - 4p 71
	3p - 4p 79

Fixing on DIN 50022 rail


- Key
 1 Bracket for fixing
 2 Overall dimensions of wiring ducts
 3 Phase separators 25mm
 4 Optional front cover for DIN rail




Tmax XT1 – Installation

Installation for fixed circuit-breaker

Drilling templates for circuit-breaker fixing




Flanges




Compartment door drilling templates


With standard flange




A=74
3 POLES




A=74
4 POLES




Without flange



A=71
3 POLES




A=71
4 POLES




A=79
3-4 POLES

With optional flange



A=79
3-4 POLES




Tmax XT1 – Installation

Terminals for fixed circuit-breaker


Terminals F

- Key
1 Front terminals for busbars connection
7 Phase separators 25mm




Terminals EF

- Key
2 Front extended terminals
3 High terminal covers with degree of protection IP40
5 Phase separators 100mm
9 Internal insulating plate





Terminals ES

- Key
4 Front extended spread terminals for busbar connection
6 Phase separators 200mm





1x1.5...50mm² terminals FCCuAl

—
Key
1 1x1.5...50mm² front terminal FCCuAl
3 Phase separators 25mm





1x35...95mm² terminals FCCuAl

—
Key
1 External terminal FCCuAl
2 High terminal covers with degree of protection IP40





Terminals FCCu

—
Key
2 Front terminal FCCu



Terminals MC


—
Key
4 Terminal covers with degree of protection IP40
5 Front terminal for multicable connection



Tmax XT1 – Installation

Terminals for fixed circuit-breaker


Terminals R



Tmax XT1 – Installation

Accessories for fixed circuit-breaker

Rotary handle operating mechanism on circuit-breakers (RHD)




—
Key

- Key
 - 2 Rotary handle operating mechanism on circuit-breaker RHD
 - 4 Door drilling template with direct rotary handle
 - 6 Phase separators 25mm

Tmax XT1 – Installation

Accessories for fixed circuit-breaker



Rotary handle operating mechanism on the compartment door (RHE)



Key

- 1 Transmitted rotary handle
- 3 Door drilling template with transmitted rotary handle
- 5 Transmission unit
- 6 Phase separators 25mm

Large rotary handle operating mechanism on the compartment door (RHE-LH)




- Key**
- Transmission unit
 - Phase separators
25mm
 - Optional wiring ducts
 - Wide type rotary handle
 - Door drilling template with transmitted rotary handle

Tmax XT1 – Installation

Accessories for fixed circuit-breaker


Large rotary handle operating mechanism on the compartment door
(RHE-LH)



Key

- 1 Transmission unit
- 2 Phase separators
25mm
- 3 Optional wiring ducts
- 4 Wide type rotary
handle
- 5 Door drilling
template with
transmitted rotary
handle

Direct motor operator (MOD)









Key

- 3 Key lock
- 4 Direct motor operator (MOD)
- 5 Drilling template of door with MOD without flange
- 6 Drilling template of door with MOD with flange
- 7 Cables connection
- 8 Phase separators 25mm

Tmax XT1 – Installation

Accessories for fixed circuit-breaker


RC Inst and RC Sel residual current release for 3 poles circuit-breaker



- Key**
- 1 Front terminals for busbars connection
 - 2 Terminal covers with degree of protection IP40
 - 3 Drilling template of door with direct rotary handle with flange
 - 4 Drilling template of door with direct rotary handle without flange
 - 5 Drilling template for circuit-breaker fixing on sheet

	A
With standard flange	3p 74
Without flange	3p 71


RC Inst and RC Sel residual current release for 4 poles circuit-breaker



Tmax XT1 – Installation

Accessories for fixed circuit-breaker

RC Sel 200 4 poles residual current release





Tmax XT1 – Installation







Installation for plug-in circuit-breaker

Fixing on support sheet

—	Key
1	Fixed part
2	Moving part
—	
A	
With standard 3p-4p 124 flange	
Without flange 3p-4p 121	3p-4p 129
—	
A	
With standard 3p-4p 144 flange	
Without flange 3p-4p 141	3p-4p 149








Drilling templates for fixing circuit-breaker



Tmax XT1 – Installation

Installation for plug-in circuit-breaker

Flanges




—

Key


- 1 Flange for plug-in circuit-breaker 3p
- 2 Flange for circuit-breaker 4p
- 5 Flange for plug-in circuit-breaker 3p-4p with direct motor operator (MOD)
- 6 Flange for plug-in circuit-breaker 3p-4p with direct rotary handle RHD
- 7 Optional flange

Compartment door drilling templates



With standard flange



Without flange




With optional flange



Tmax XT1 – Installation


Terminals for plug-in circuit-breaker

Terminals EF



Key
 4 Front extended terminals
 5 Phase separators 100mm



Terminals ES



Key
 3 Front extended spread terminals
 6 Phase separators 200mm
 7 Adaptor

1x1.5...50mm² terminals FCCuAl



—
Key
1 1x1.5...50mm² front terminal FCCuAl
5 Adaptor
6 Phase separators 25mm



FIXING AT 50mm



1x35...95mm² terminals FCCuAl

—
Key
1 External terminal FCCuAl
2 High terminal covers with degree of protection IP40



Terminals FCCu

—
Key
4 Terminals FCCu
5 Adaptor
6 Phase separators 25mm





FIXING AT 50mm

Tmax XT1 – Installation

Terminals for plug-in circuit-breaker




Terminals MC

Key
 2 Terminal covers
 with degree of
 protection IP40
 3 Front terminal
 for multicable
 connection
 5 Adaptor



FIXING AT 50mm



Terminals HR/VR



FIXING AT 50mm

FIXING AT 50mm



Key
 1 Rear vertical
 terminals
 2 Rear horizontal
 terminals
 3 Rear phase
 separators 90mm



Tmax XT1 – Installation

Accessories for plug-in circuit-breaker

Direct motor operator (MOD)



—
Key

- Key
 - 1 Fixed part
 - 2 Moving part
 - 3 Key lock
 - 4 Direct motor operator (MOD)
 - 5 Drilling template of door with MOD without flange
 - 6 Drilling template of door with MOD with flange
 - 7 Cable connection


Tmax XT2 – Installation

Installation for fixed circuit-breaker

Fixed circuit-breaker fixing on sheet


Key
 2 Optional wiring ducts
 3 Phase separators
 25mm

A
 With standard 3p-4p 86 flange
 Without flange 3p-4p 83.5
 3p-4p 91.5




With side connector for Ekip Touch trip units

Key
 1 Front terminals
 2 Flange for 4p circuit-breaker
 3 Flange for 3p circuit-breaker
 7 Tightening torque 1,1 Nm - 10 In.Lbs
 8 Tightening torque 6 Nm - 53 In.Lbs
 9 Optional wiring duct
 10 Phase separators 25mm
 11 Rear plate insulating 3p (UL version only)
 12 Rear plate insulating 4p (UL version only)
 15 Connection kit F/P IntBus/ExtNeut/Sel




Key
 1 Bracket for fixing
 3 Phase separators 25mm


Fixed circuit-breaker fixing on DIN EN 50022 rail




Drilling templates and support sheet









3 POLES



4 POLES



Flanges



Key


- 1 Flange for fixed circuit-breaker 3p
- 2 Flange for fixed circuit-breaker 4p
- 3 Flange for fixed circuit-breaker 3p-4p with MOE and FLD
- 4 Flange for circuit-breaker 3p-4p with direct rotary handle RHD
- 8 Flange for circuit-breaker 4p with fixed residual current and front terminals
- 9 Optional flange

Tmax XT2 – Installation


Installation for fixed circuit-breaker

Compartment door drilling templates

With standard flange




Without flange




With optional flange

Key
1 Optional flange



	Execution	A	B	C
With fixed flange	fixed	92	3-4 poles	
With optional flange	plug-in, fixing at 50mm	142	3-4 poles	
With optional flange	plug-in, fixing at 70mm	162	3-4 poles	




Tmax XT2 – Installation

Terminals for fixed circuit-breaker


Terminals F

- Key
1 Phase separators
25mm
2 Front terminals for
busbars connection



Terminals EF

- Key
3 Front extended
terminals
4 Terminal covers
with degree of
protection IP40
5 Phase separators
100mm
6 Insulated plate
7 Drilling template for
3p circuit-breaker
Ue>440V
8 Drilling template
for 4p circuit-
breaker Ue>440V




Tmax XT2 – Installation

Terminals for fixed circuit-breaker


Terminals ES

- Key
 1 Drilling template for 3p circuit-breaker Ue>440V
 2 Drilling template for 4p circuit-breaker Ue>440V
 3 Front extended spread terminals
 4 Phase separators 200mm
 5 Insulated plate





1x1...95mm² terminals FCCuAl

- Key
 1 1x1...95mm² terminals FCCuAl
 3 Phase separators 25mm






1x70...185mm² terminals FCCuAl

- Key
 1 External terminal FCCuAl
 2 High terminal covers with degree of protection IP40



2x35...70mm² terminals FCCuAl

- Key
 2 2x35...70mm² terminals FCCuAl
 4 Terminal covers with degree of protection IP40



Terminals FCCu



- Key
 3 Phase separators 25mm
 6 Terminals FCCu








Tmax XT2 – Installation

Terminals for fixed circuit-breaker

Terminals MC




Terminals R



Tmax XT2 – Installation

Accessories for fixed circuit-breaker

Rotary handle operating mechanism on circuit-breaker (RHD)



—
Key


- Key

 - 2 Rotary handle
operating mechanism
on circuit-breaker
 - 4 Drilling template
of door with direct
rotary handle
 - 6 Phase separators
25mm

Tmax XT2 – Installation

Accessories for fixed circuit-breaker


Rotary handle operating mechanism on the compartment door (RHE)



Key


- 1 Transmission mechanism
- 2 Rotary handle operating mechanism for compartment door
- 3 Compartment door drilling template
- 4 Tightening torque 1.1Nm

Stored energy motor operator (MOE)




- Key**
- 1 Stored energy motor operator (MOE)
 - 2 Key lock
 - 3 Drilling template of door with MOE with flange
 - 4 Door drilling template with MOE without flange
 - 5 Drilling template for circuit-breaker 3p fixing on sheet
 - 6 Drilling template for circuit-breaker 4p fixing on sheet
 - 7 Phase separators 25mm

3 POLES




4 POLES



Tmax XT2 – Installation

Accessories for fixed circuit-breaker


Front for lever operating mechanism (FLD)



Key

- 1 Key lock
- 2 Front for lever operating mechanism (FLD)
- 3 Drilling template of door with FLD with flange
- 4 Drilling template of door with FLD without flange
- 5 Phase separators 25mm

Ekip Display or Ekip LED Meter




Key

- 1 Phase separators
25mm
- 2 Ekip Display or
Ekip LED Meter

Tmax XT2 – Installation

Accessories for fixed circuit-breaker

Residual current RC Sel



Tmax XT2 – Installation

Installation for plug-in circuit-breaker



Plug-in circuit-breaker fixing on sheet

—
Key
1 Fixed part
2 Moving part

Fixing at 50mm A

With standard 3p-4p 136 flange

Without flange 3p-4p 133.5
3p-4p 141.5






Fixing at 70mm for extended A front terminals

With standard 3p-4p 156 flange

Without flange 3p-4p 153.5
3p-4p 161.5

With side connector for Ekip Touch trip units




—
Key
9 Optional wiring duct
10 Phase separators 25mm
15 Connection kit F/P IntBus/ExtNeut/Sel







Tmax XT2 – Installation

Installation for plug-in circuit-breaker

Drilling templates for support sheet



Flanges




- Key**
- 1 Flange for removable circuit-breaker 3p
 - 2 Flange for circuit-breaker 4p
 - 3 Flange for plug-in circuit-breaker 3p-4p with MOE and FLD
 - 4 Flange for circuit-breaker 3p-4p with direct rotary handle (RHD)
 - 8 Flange for circuit-breaker 4p with residual current and plug-in with front terminals
 - 9 Optional flange

Tmax XT2 – Installation


Installation for plug-in circuit-breaker

Compartment door drilling templates


With standard flange



Without flange



With optional flange




Tmax XT2 – Installation

Terminals for plug-in circuit-breaker



Terminals EF

—
Key
4 Front extended terminals
5 Phase separators 100mm



Terminals ES

—
Key
1 Front extended spread terminals
2 Phase separators 200mm
3 Insulated plate
4 Drilling template for 3p circuit-breaker Ue>440V
5 Drilling template for 4p circuit-breaker Ue>440V





Tmax XT2 – Installation

Terminals for plug-in circuit-breaker



1x1...95mm² terminals FCCuAl

- Key
1 1x1...95mm² front terminal FCCuAl
2 Phase separators 25mm
6 Adaptor





1x70...185mm² terminals FCCuAl

- Key
1 External terminal FCCuAl
2 High terminal covers with degree of protection IP40



2x35...70mm² terminals FCCuAl



- Key
1 External terminal FCCuAl
2 High terminal covers with degree of protection IP40



Terminals FCCu



—
Key
3 Terminals FCCu
4 Adaptor

—
Note:
Phase separators 25mm



FIXING AT 50mm

Terminals MC





FIXING AT 50mm

—
Key
3 High terminal covers
with degree of
protection IP40
4 Multicable terminals
6 Adaptor


Tmax XT2 – Installation

Terminals for plug-in circuit-breaker



Terminals HR/VR



FIXING AT 50mm



FIXING AT 50mm



—


Key

- 1 Rear vertical terminals
- 2 Rear horizontal terminals
- 3 Rear phase separators 90mm

Tmax XT2 – Installation

Accessories for plug-in circuit-breaker

Stored energy motor operator (MOE)




Key

- 1 Fixed part
- 2 Moving part
- 3 MOE
- 4 Key lock
- 5 Phase separators
100mm
- 6 Drilling template
of door with direct
rotary handle
with flange
- 7 Drilling template
of door with direct
rotary handle
without flange

Tmax XT2 – Installation



Accessories for plug-in circuit-breaker

Front for lever operating mechanism (FLD)




- Key**
- 1 Fixed part
 - 2 Moving part
 - 3 Front for lever operating mechanism (FLD)
 - 4 Key lock
 - 5 Phase separators 100mm
 - 6 Drilling template of door with direct rotary handle with flange
 - 7 Drilling template of door with direct rotary handle without flange

Ekip Display or Ekip LED Meter



FIXING AT 50mm




FIXING AT 50mm

Key
 1 Phase separators
 100mm
 2 Ekip Display or
 Ekip LED Meter


Tmax XT2 – Installation

Accessories for plug-in circuit-breaker

Residual current RC Sel



- Key**
- 1 Residual current
 - 3 Fixed part
 - 4 Moving part
 - 5 Phase separators
100mm
 - 6 Extended terminals
 - 7 Drilling template
of door with direct
rotary handle and
fixing with flange
 - 8 Drilling template
of door with direct
rotary handle and
fixing without flange
 - 9 Drilling template
for circuit-breaker
fixing on sheet





	A
With standard flange	4p 136
Without flange	4p 133.5

Tmax XT2 – Installation

Installation for withdrawable circuit-breaker

Fixing on sheet



—



Key

- 1 Fixed part
 - 2 Moving part
 - 3 FLD (FLD o RHD
 - o RHE o MOE)
 - mandatory for withdrawable version
 - 6 Optional wiring ducts

Tmax XT2 – Installation

Installation for withdrawable circuit-breaker

With side connector for Ekip Touch trip units




	A	
With standard flange	3p - 4p	Fixing at 50mm 170
	3p - 4p	Fixing at 70mm for extended front terminals 190


Key

- 1 Fixed part
- 2 Moving part
- 3 FLD (FLD o RHD
o RHE o MOE)
mandatory for withdrawable version
- 10 Optional Wiring Duct
- 13 Connection Kit W IntBus/ExtNeut/Sel

Drilling templates for support sheet



Flanges




Tmax XT2 – Installation


Installation for withdrawable circuit-breaker

Compartment door drilling templates


With standard flange



Without flange




With standard flange



Tmax XT2 – Installation

Terminals for withdrawable circuit-breaker

Terminals EF




- **Key**
- 2 Moving part
 - 3 FLD (FLD or RHD or RHE or MOE) mandatory for withdrawable version
 - 4 Front extended terminals
 - 5 Phase separators 100mm

—
 Note:
 insulated plate


Tmax XT2 – Installation

Terminals for withdrawable circuit-breaker

Terminals ES





FIXING AT 50mm



- Key**
- 1 Phase separators
200mm
 - 3 Front extended
spread terminals
 - 5 Adaptor
 - 6 Insulated plate
 - 7 Drilling template
for 3p circuit-
breaker Ue>440V
 - 8 Drilling template
for 4p circuit-
breaker Ue>440V

1x1...95mm² terminals FCCuAl



—
Key
2 Phase separators
25mm
4 1x1...95mm² front terminals FCCuAl
5 Adaptor





FIXING AT 50mm

1x70...185mm² terminals FCCuAl

—
Key
1 External terminal
FCCuAl
2 High terminal covers
with degree of
protection IP40

2x35...70mm² terminals FCCuAl

—
Key
1 External terminal
FCCuAl 2x70mm²
2 High terminal covers
with degree of
protection IP40





Tmax XT2 – Installation

Terminals for withdrawable circuit-breaker



Terminals FCCu

- Key
2 Terminals FCCu
4 Adaptor
5 Phase separators
25mm



FIXING AT 50mm


Terminals MC



FIXING AT 50mm


- Key
1 Multicable terminals
3 High terminal covers
with degree of
protection IP40
4 Adaptor

Terminals HR/VR



FIXING AT 50mm

FIXING AT 50mm




Key

- 1 Rear vertical terminals
- 2 Rear horizontal terminals
- 3 Rear phase separators 90mm


Tmax XT2 – Installation

Accessories for withdrawable circuit-breaker

Rotary handle operating mechanism on circuit-breakers (RHD)




Rotary handle operating mechanism on the compartment door (RHE)





Tmax XT2 – Installation

Accessories for withdrawable circuit-breaker

Stored energy motor operator (MOE)



Front for lever operating (FLD)



Key


- 1 Fixed part
- 2 Moving part
- 3 Front for lever operating (FLD)
- 4 Phase separators 100mm
- 5 Extended terminals
- 6 Key lock

A
Front for lever operating FLD 3p-4p 170

Tmax XT2 – Installation

Accessories for withdrawable circuit-breaker

Residual current RC Sel 4 poles




Tmax XT3 – Installation

Installation for fixed circuit-breaker

Fixing on sheet


- Key
2 Overall dimensions of optional wiring ducts
3 Phase separators 25mm



	A
With standard flange	3p - 4p 74
Without flange	3p - 4p 71
	3p - 4p 79

Fixing on DIN EN 50022 rail



- Key
1 Bracket for fixing
2 Optional wiring ducts
3 Optional front cover for DIN rail
4 Phase separators 25mm



Tmax XT3 – Installation

Installation for fixed circuit-breaker








Drilling templates for circuit-breaker fixing



Flanges


Key

- 1 Flange for fixed circuit-breaker 3p
- 2 Flange for fixed circuit-breaker 4p
- 3 Flange for circuit-breaker with direct motor operator MOD
- 4 Flange for circuit-breaker with direct rotary handle (RHD)
- 5 Flange for circuit-breaker 3p with residual current
- 6 Flange for circuit-breaker 4p with residual current
- 7 Optional flange




Compartment door drilling templates


With standard flange




A=74
3 POLES




A=74
4 POLES




Without flange



A=71
3 POLES




A=71
4 POLES




A=79
3-4 POLES

With optional flange



A=79
3-4 POLES





Key
1 Optional flange

Tmax XT3 – Installation

Terminals for fixed circuit-breaker



Terminals F

—
Key
 1 Front terminals for busbars connection
 7 Phase separators 25mm






Terminals EF

—
Key
 2 Front extended terminals
 3 Terminal covers with degree of protection IP40 (optional) not provided
 5 Phase separators 100mm








Terminals ES

—
Key
 4 Front extended spread terminals for busbars connection
 6 Phase separators 200mm





1x95...185mm² terminals FCCuAl

Key
 1 1x95...185mm²
 terminals FCCuAl
 9 Phase separators
 25mm

2x35...120mm² terminals FCCuAl

Key
 2 2x35...120mm²
 terminals FCCuAl
 3 Terminal covers
 with degree of
 protection IP40
 4 Rear insulated plate
 7 Drilling template for
 circuit-breaker fixing
 on sheet 3p with
 rear insulated plate
 8 Drilling template for
 circuit-breaker fixing
 on sheet 4p with
 rear insulated plate





Tmax XT3 – Installation

Terminals for fixed circuit-breaker


30...150mm² terminals FCCuAl

- Key
1 30...150mm²
terminals FCCuAl
2 Phase separators
25mm





Terminals FCCu

- Key
6 Front terminals FCCu
9 Phase separators
25mm




Terminals MC

- Key
3 Terminal covers
with degree of
protection IP40
5 Front terminal
for multicable
connection





Terminals R



Tmax XT3 – Installation


Accessories for fixed circuit-breaker

Rotary handle operating mechanism on circuit-breaker (RHD)



- Key**
- 2 Rotary handle operating mechanism on circuit-breaker RHD
 - 4 Drilling template of door with direct rotary handle
 - 6 Phase separators 25mm

Rotary handle operating mechanism on the compartment door (RHE)




Key

- 1 Transmission mechanism
- 2 Rotary handle operating mechanism for compartment door (RHE)
- 3 Compartment door drilling template
- 4 Tightening torque 1.1Nm

Tmax XT3 – Installation

Accessories for fixed circuit-breaker


Large rotary handle operating mechanism on the compartment door (RHE-LH)



- Key**
- 1 Transmission unit
 - 2 Phase separators
25mm
 - 3 Optional wiring ducts
 - 4 Large transmitted
rotary handle
 - 5 Drilling template of
door with large
transmitted
rotary handle

MINIMUM DISTANCE FROM DOOR HINGE min 200

Direct motor operator (MOD)




Key

- 3 Key lock
- 4 Direct motor operator MOD
- 5 Drilling template of door with MOD with flange
- 6 Drilling template of door with MOD without flange
- 7 Phase separators 25mm


Tmax XT3 – Installation

Accessories for fixed circuit-breaker

RC Inst and RC Sel residual current release for 3 poles circuit-breaker




RC Inst and RC Sel residual current release for 4 poles circuit-breaker



Tmax XT3 – Installation

Installation for plug-in circuit-breaker

Fixing on support sheet




Fixing at 50mm	A
With standard flange	3p-4p 124
	3p-4p 121
Without flange	3p-4p 129

Fixing at 70mm for extended front terminals	A
With standard flange	3p-4p 144
	3p-4p 141
Without flange	3p-4p 149


—
Key
1 Fixed part
2 Moving part

Drilling templates for support sheet



Flanges

- Key
- 1 Flange for plug-in circuit-breaker 3p
 - 2 Flange for plug-in circuit-breaker 4p
 - 3 Flange for plug-in circuit-breaker with direct motor operator MOD
 - 7 Optional flange




Tmax XT3 – Installation


Installation for plug-in circuit-breaker

Compartment door drilling templates


With standard flange



Without flange




With optional flange



Tmax XT3 – Installation


Terminals for plug-in circuit-breaker

Terminals EF



Key
 4 Front extended terminals
 5 Phase separators
 100mm

Terminals ES





Key
 3 Front extended spread terminals for busbars connection
 5 Adapter for fixed part (compulsory) not provided
 6 Phase separators 200mm

Tmax XT3 – Installation

Terminals for plug-in circuit-breaker


1x95...185mm² terminals FCCuAl

—
Key
 1 1x95...185mm² front terminal FCCuAl
 5 Adapter for fixed part
 6 Phase separators 25mm





2x35...120mm² terminals FCCuAl

—
Key
 1 2x35...120 mm² external terminal FCCuAl
 2 High terminal covers with degree of protection IP40
 3 Rear insulated plate
 4 Drilling template for fixing circuit-breaker 3p with rear insulated plate
 5 Drilling template for fixing circuit-breaker 4p with rear insulated plate





30...150mm² terminals FCCuAl

- Key
 1 30...150mm²
 terminals FCCuAl
 2 Phase separators
 25mm
 3 Adapter for fixed part





Terminals FCCu

- Key
 4 Front terminals FCCu
 5 Adapter for fixed part
 6 Phase separators
 25mm



Terminals MC


- Key
 2 High terminal covers
 with degree of
 protection IP40
 3 Front terminal
 for multicable
 connection
 5 Adapter for fixed part



Tmax XT3 – Installation

Terminals for plug-in circuit-breaker

Terminals HR/VR



Key
 1 Rear vertical terminals
 2 Rear horizontal terminals
 3 Rear phase separators 90mm



FIXING AT 50mm

FIXING AT 50mm



Tmax XT3 – Installation

Accessories for plug-in circuit-breaker

Direct motor operator (MOD)



FIXING AT 50mm



Key

- 1 Fixed part
- 2 Moving part
- 3 Key lock
- 4 Direct motor operator MOD
- 5 Drilling template of door with MOD with flange
- 6 Drilling template of door with MOD without flange


Tmax XT4 – Installation

Installation for fixed circuit-breaker

Fixing on sheet


-
- Key
- 2 Overall dimensions of optional wiring ducts
- 3 Phase separators
25mm

A
With standard 3p-4p 86 flange
Without flange 3p-4p 83.5 3p-4p 91.5




With side connector for Ekip Touch trip units

-
- Key**
- 1 Front terminals
- 2 Flange for 4p circuit-breaker
- 3 Flange for 3p circuit-breaker
- 7 Tightening torque
1,1 Nm - 10 In.Lbs
- 8 Tightening torque
8 Nm - 70.3 In.Lbs
- 9 Optional wiring duct
- 10 Phase separators
25mm
- 11 Rear plate insulating
3p (only ul version)
- 12 Rear plate insulating
4p (only ul version)
- 15 Connection kit F/P
IntBus/ExtNeut/Sel




Fixing on DIN 50022 rail


—
Key
1 Bracket for fixing
3 Phase separators
25mm



Drilling templates for support sheet



Flanges



Key


- 1 Flange for fixed circuit-breaker 3p
- 2 Flange for fixed circuit-breaker 4p
- 3 Flange for fixed circuit-breaker 3p-4p with MOE and FLD
- 4 Flange for circuit-breaker 3p-4p with direct rotary handle RHD
- 7 Flange for fixed circuit-breaker 4p with front extended terminals and residual current
- 8 Optional flange

Tmax XT4 – Installation


Installation for fixed circuit-breaker

Compartment door drilling templates


With standard flange



Without flange



With optional flange




Tmax XT4 – Installation

Terminals for fixed circuit-breaker


Terminals F

- Key
1 Phase separators
25mm
2 Top terminal covers with degree of protection IP30



Terminals EF

- Key
3 Front extended terminals
4 Terminal covers with degree of protection IP40
5 Phase separators
100mm
6 Insulated plate
7 Drilling template for 3p circuit-breaker
8 Drilling template for 4p circuit-breaker





Tmax XT4 – Installation

Terminals for fixed circuit-breaker


Terminals ES


- Key
 1 Drilling template for 3p circuit-breaker
 2 Drilling template for 4p circuit-breaker
 3 Front extended spread terminals
 4 Phase separators 200mm
 5 Insulating plate



1x1...185mm² terminals FCCuAl

- Key
 1 1x1...185mm² terminals FCCuAl
 3 Phase separators 25mm



2x35...120mm² terminals FCCuAl

—

Key
2 2x35...120mm²
terminals FCCuAl

4 Terminal covers with
degree of protection
IP40

5 Rear insulated plate

6 Drilling template
for circuit-breaker 4p
fixing with insulating
plate



7 Drilling template
for circuit-breaker 3p
fixing with insulating
plate

Tmax XT4 – Installation

Terminals for fixed circuit-breaker



Terminals FCCu

—
Key
1 Terminals FCCu
4 Phase separators
25mm
25mm




Terminals MC

—
Key
2 Multicable terminals
3 Terminal covers
with degree of
protection IP40




Terminals R



Tmax XT4 – Installation


Accessories for fixed circuit-breaker

Rotary handle operating mechanism on circuit-breaker (RHD)



- Key**
- 2 Rotary handle operating mechanism on circuit-breaker
 - 4 Drilling template of door with direct rotary handle
 - 6 Phase separators 25mm

Rotary handle operating mechanism of the compartment door (RHE)




Key

- 1 Rotary handle operating mechanism of the compartment door
- 2 Drilling template for RHE
- 3 Transmission unit
- 4 Phase separators 25mm


Tmax XT4 – Installation

Accessories for fixed circuit-breaker


Stored energy motor operator (MOE)



- Key**
- 1 Stored energy motor operator (MOE)
 - 2 Key lock
 - 3 Drilling template of door with flange (MOE)
 - 4 Drilling template of door without flange (MOE)
 - 5 Drilling template for circuit-breaker 3p fixing on sheet
 - 6 Drilling template for circuit-breaker 4p fixing on sheet
 - 7 Phase separators 25mm




3 POLES



4 POLES


Front for lever operating mechanism (FLD)



Tmax XT4 – Installation

Accessories for fixed circuit-breaker


Ekip Display or LED Meter



Key

- 1 Ekip Display or LED Meter
- 2 Optional wiring ducts
- 3 Phase separators 25mm

Residual current RC Sel




Tmax XT4 – Installation

Installation for plug-in circuit-breaker

Fixing on sheet

—
Key
1 Fixed part
2 Moving part




Fixing at 50mm		A
With standard flange	3p-4p	136
	3p-4p	133.5
Without flange	3p-4p	141.5



Fixing at 70mm for extended front terminals		A
With standard flange	3p-4p	156
	3p-4p	153.5
Without flange	3p-4p	161.5

With side connector for Ekip Touch trip units

—
Key
1 Front terminals
2 Flange for 4p circuit-breaker
9 Optional wiring duct
10 Phase separators 25mm
15 Connection kit F/P IntBus/ExtNeut/Sel









Drilling templates for support sheet



Tmax XT4 – Installation

Installation for plug-in circuit-breaker

Flanges




Key


- 1 Flange for plug-in circuit-breaker 3p
- 2 Flange for plug-in circuit-breaker 4p
- 3 Flange for plug-in circuit-breaker 3p-4p with MOE and FLD
- 4 Flange for circuit-breaker 3p-4p with direct rotary handle
- 7 Flange for plug-in circuit-breaker 4p with front extended terminals and residual current
- 8 Optional flange

Compartment door drilling templates


With standard flange



Without flange




With optional flange



Tmax XT4 – Installation

Terminals for plug-in circuit-breaker




Terminals EF



—
Key
4 Front extended terminals
5 Phase separators 100mm

—
Note:
insulated plate

Terminals ES





- Key
- 1 Front extended spread terminals
 - 2 Phase separators 200mm
 - 3 Insulated plate provided
 - 4 Drilling template for 3p circuit-breaker
 - 5 Drilling template for 4p circuit-breaker
 - 6 Adaptor

Tmax XT4 – Installation

Terminals for plug-in circuit-breaker

1x1...185mm² terminals FCCuAl



—
Key
1 1x1...185mm² front terminals FCCuAl
2 Phase separators 25mm
6 Adaptor



FIXING AT 50mm

2x35...120mm² terminals FCCuAl



—
Key
1 2x120mm² external terminal FCCuAl
2 High terminal covers with degree of protection IP40



FIXING AT 50mm

Terminals FCCu


—
Key
2 Phase separators 25mm
5 Terminals FCCu
6 Adaptor



FIXING AT 50mm


Terminals MC

Key
 3 High terminal covers with degree of protection IP40
 4 Multicable terminals
 6 Adaptor



FIXING AT 50mm



Terminals HR/VR



FIXING AT 50mm

FIXING AT 50mm


Key
 1 Rear vertical terminals
 2 Rear horizontal terminals
 3 Rear phase separators 90mm



Tmax XT4 – Installation


Accessories for plug-in circuit-breaker

Stored energy motor operator (MOE)



- Key**
- 1 Fixed part
 - 2 Moving part
 - 3 Stored energy motor operator (MOE)
 - 4 Key lock
 - 5 Phase separators 100mm
 - 6 Drilling template of door with flange
 - 7 Drilling template of door without flange
 - 8 Extended terminals


Front for lever operating mechanism (FLD)




Tmax XT4 – Installation

Accessories for plug-in circuit-breaker






Ekip Display or LED Meter



Key
1 Phase separators
100mm
2 Ekip Display or
LED Meter



Residual current RC Sel




- Key**
- 1 Residual current
 - 3 Fixed part
 - 4 Moving part
 - 5 Phase separators
100mm
 - 6 Extended terminals
 - 7 Drilling template of
door with flange
 - 8 Drilling template of
door without flange
 - 9 Drilling template
for circuit-breaker
fixing on sheet

Fixing at 50mm	B
With standard flange	4p 136
Without flange	4p 133.5

Tmax XT4 – Installation

Installation for withdrawable circuit-breaker

Fixing on sheet





	A		
	3p - 4p	Fixing at 50mm	170
With standard flange		Fixing at 70mm for front extended terminals	190
	3p - 4p		

Key

- 1 Fixed part
- 2 Moving part
- 3 FLD (FLD or RHD or RHE or MOE)
mandatory with withdrawable version
- 6 Optional wiring ducts

With side connector for Ekip Touch trip units



	A	
With standard flange	3p - 4p	Fixing at 50mm 170
	3p - 4p	Fixing at 70mm for front extended terminals 190


Key

- 1 Fixed part
- 2 Moving part
- 3 FLD (FLD or RHD or RHE or MOE) mandatory with withdrawable version
- 4 Flange
- 9 Optional wiring ducts
- 12 Connection kit W IntBus/ExtNeut/Sel

Tmax XT4 – Installation


Installation for withdrawable circuit-breaker

Drilling templates for support sheet



Flanges


- Key
- 5 Flange for withdrawable circuit-breaker 3p-4p
 - 6 Flange for residual current release (withdrawable 4p circuit-breaker) with front extended terminals




	C	D
RHD	111	124.5
FLD - MOE	114.3	134.5

Compartment door drilling templates


With standard flange



Without flange




With optional flange



Tmax XT4 – Installation

Terminals for withdrawable circuit-breaker



Terminals EF



—
Key
4 Front extended terminals
5 Phase separators 100mm

—
Note:
insulated plate

Terminals ES




- Key
- 1 Front extended spread terminals
 - 2 Phase separators 200mm
 - 3 Insulated plate
 - 4 Drilling template for 3p circuit-breaker
 - 5 Drilling template for 4p circuit-breaker
 - 6 Adaptor

Tmax XT4 – Installation

Terminals for withdrawable circuit-breaker

1x1...185mm² terminals FCCuAI


- Key
2 Phase separators
25mm
4 Front terminals
FCCuAI
5 Adaptor



FIXING AT 50 mm



2x35...120mm² terminals FCCuAI

- Key
1 2x35...120mm²
terminals
FCCuAI
2 Terminal covers
with degree of
protection IP40
3 Rear insulated plate
4 Drilling template
for circuit-breaker
3p fixing with
insulating plate
5 Drilling template
for circuit-breaker
4p fixing with
insulating plate



Terminals FCCu



—
Key
 1 Phase separators 25mm
 2 Terminals FCCu
 3 Adaptor



FIXING AT 50 mm

Terminals MC

—
Key
 1 Multicable terminals
 3 High terminal covers with degree of protection IP40
 4 Adaptor




FIXING AT 50 mm

Tmax XT4 – Installation

Terminals for withdrawable circuit-breaker

Terminals HR/VR



FIXING AT 50 mm


FIXING AT 50 mm

- Key
- 1 Rear vertical terminals
 - 2 Rear horizontal terminals
 - 3 Rear phase separators 90mm

Tmax XT4 – Installation

Accessories for withdrawable circuit-breaker


Front for lever operating mechanism (FLD)




Tmax XT4 – Installation

Accessories for withdrawable circuit-breaker

Stored energy motor operator (MOE)



Rotary handle operating mechanism on circuit-breakers (RHD)




Key

- 1 Fixed part
- 2 Moving part
- 4 Tightening
torque 1.1 Nm
- 5 Flange for the
compartment door
- 6 Rotary handle
operating mechanism
for circuit-breaker

Tmax XT4 – Installation

Accessories for withdrawable circuit-breaker

Rotary handle operating mechanism on the compartment door (RHE)




Key

- 1 Fixed part
- 2 Moving part
- 3 Compartment door drilling template-for fixed part
- 4 Tightening torque 1.1 Nm
- 5 Tightening torque 1.4 Nm
- 6 Transmission mechanism
- 7 Rotary handle operating mechanism for compartment door
- 8 Compartment door drilling template

	F
Fixing 3 poles	107
Fixing 4 poles	142


Residual current RC Sel 4 poles



Tmax XT5 – Installation


Installation for fixed circuit-breaker

Fixing on sheet




Drilling templates for support sheet

Key	
1	Front terminals for flat connection
2	Busbar
3	Flange without gasket for the compartment door
6	Tightening torque 36Nm
7	Tightening torque 2Nm
9	Phase separators 25mm
11	Cable rack
12	Rear insulating plate




Flange

Key
3 Flange without gasket for the compartment door



Drilling template compartment door

Key
8 Compartment door drilling template with/without flange




	A [mm]	B [mm]	C [mm]	D [mm]
With flange 3p - 4p	174	152	87	76
Without flange 3p - 4p	165	143	82.5	71.5

Tmax XT5 – Installation

Terminals for fixed circuit-breaker


Terminals EF



Key

- 1 Extended front terminals
- 2 Flange for the compartment door
- 5 Tightening torque 36Nm
- 6 Tightening torque 2Nm
- 8 High terminal cover
- 9 Phase separators 100mm
- 10 Cable rack
- 12 Rear insulating plate

Terminals ES




Key

- 1 Extended front terminals
- 2 Flange for the compartment door
- 5 Tightening torque 18Nm
- 6 Tightening torque 2Nm
- 8 Rear insulating plate
- 9 Phase separators 200mm
- 10 Cable rack
- 12 Rear insulating plate

Tmax XT5 – Installation

Terminals for fixed circuit-breaker

1 x 120...240mm² and 1 x 35...185mm² terminals FC CuAl




—

Key

- 1 Terminals FCCuAl
1x120...240mm²
- 2 Flange for the compartment door
- 5 Tightening torque
23Nm
- 6 Tightening
torque 2Nm
- 8 Terminals FCCuAl
1x35...185mm²
- 9 Tightening torque
23Nm
- 10 Cable rack
- 12 Rear insulating plate
- 13 Phase separators
25mm

2 x 70...240mm² terminals FC CuAl



—


Key

- 1 Terminals FCCuAl
2x240mm
- 2 Flange for the
compartment door
- 5 Tightening
torque 36Nm
- 6 Tightening
torque 2Nm
- 7 Compartment door
drilling template for
flange without gasket
- 8 Phase separators
100mm
- 9 Tightening
torque 31Nm
- 10 Cable rack
- 13 High terminal cover
- 14 Segregation form
4 (optional)

Tmax XT5 – Installation

Terminals for fixed circuit-breaker

Terminals R




—
Key


- 1 Rear terminals (horizontal and vertical)
- 2 Flange without gasket for the compartment door
- 5 Tightening torque 18Nm
- 7 Compartment door drilling template with/without flange
- 8 Low terminal cover
- 9 Cable rack

Terminals HR upper


—
Key
6 Tightening torque 2Nm



Terminals VR lower




—
Key
3 Drilling template 3p
4 Fixing on sheet 4p




Tmax XT5 – Installation

Accessories for fixed circuit-breaker

Rotary handle operating mechanism on the circuit-breaker (RHD)




Drilling templates for support sheet




Flange

- Key
 3 Flange for the compartment door
 4 Compartment door drilling template with/without flange




Drilling template compartment door



	A [mm]	B [mm]	C [mm]	D [mm]
With flange	3p - 4p 147.5	124.3	85.8	73.75
Without flange	3p - 4p 140.5	115.3	81.3	70.25

Flange IP54

- Key
 7 IP54 flange for the compartment door
 8 Compartment door drilling template with IP54 flange






Drilling template compartment door with flange IP54

Tmax XT5 – Installation


Accessories for fixed circuit-breaker

Rotary handle operating mechanism on the compartment door (RHE)




- Key**
- 1 Circuit-breaker
 - 2 Base of rotary handle operating mechanism
 - 3 Connection rod
 - 4 Rotary handle operating mechanism of compartment door
 - 5 Compartment door drilling template
 - 6 Drilling template 3p
 - 7 Drilling template 4p

Stored energy motor operator (MOE)




Drilling templates for support sheet




Tmax XT5 – Installation

Accessories for fixed circuit-breaker

Flange




Drilling template compartment door




	A [mm]	B [mm]	C [mm]	D [mm]
With flange	3p - 4p 147.5	124.3	85.8	73.75
Without flange	3p - 4p 140.5	115.3	81.3	70.25

Residual current RC




Drilling template for support sheet




Tmax XT5 – Installation

Accessories for fixed circuit-breaker

Flange




Drilling template compartment door




	A [mm]	B [mm]	C [mm]	D [mm]	E [mm]	F [mm]	G [mm]
With flange	3p - 4p -	147.5	84.8	-	-	147.5	269.5
Without flange	3p - 4p	163.5	141.5	81.8	101.5	80.3	141.5 -

Front for lever operating mechanism (FLD)



Drilling templates for support sheet




- Key
- 1 Circuit-breaker
 - 2 Front for lever operating system (FLD)
 - 3 Flange for the compartment door
 - 4 Compartment door drilling template with/without flange
 - 5 Drilling template 3p
 - 6 Drilling template 4p
 - 7 Door lock

Tmax XT5 – Installation


Accessories for fixed circuit-breaker

Flange

—
Key
3 Flange for the compartment door
4 Compartment door drilling template with/without flange





Drilling template compartment door



	A	B	C	D
With flange	3p - 4p 147.5	124.3	85.8	73.75
Without flange	3p - 4p 140.5	115.3	81.3	70.25

Lateral rotary handle operating mechanism on the compartment door (RHL)




- Key**
- 1 Fixed part
 - 2 Moving part
 - 3 Tightening torque 2Nm
 - 4 Phase separators 100mm
 - 5 Base of rotary handle operating mechanism
 - 6 Lateral handle
 - 7 500mm connection rod
 - 8 Rotary handle on compartment door
 - 11 Compartment door drilling template

Tmax XT5 – Installation


Installation for plug-in circuit-breaker 400A

Fixing on sheet




Drilling templates for support sheet

- Key
- 1 Fixed part
 - 2 Moving part
 - 3 Tightening torque 2Nm
 - 4 Phase separators 100mm
 - 5 Compartment door drilling template with/without flange
 - 6 Flange without gasket for the compartment door
 - 7 Drilling template 3p
 - 8 Drilling template 4p




Flange



Drilling template compartment door

Key
5 Compartment door drilling template with/without flange




	A [mm]	B [mm]	C [mm]	D [mm]
With flange 3p - 4p	174	152	87	76
Without flange 3p - 4p	165	143	82.5	71.5

Tmax XT5 – Installation

Terminals for plug-in circuit-breaker 400A


Terminals EF



Key

- 1 Fixed part
- 2 Moving part
- 3 Tightening
torque 2Nm
- 4 Phase separators
100mm

Terminals HR





Key

- 1 Fixed part
- 2 Moving part
- 3 Tightening torque 2Nm
- 5 Flange without gasket for the compartment door
- 8 Rear insulating barriers (optional except same length terminals)

Tmax XT5 – Installation

Terminals for plug-in circuit-breaker 400A

Terminals VR




Key

- 1 Fixed part
- 2 Moving part
- 3 Tightening torque 2Nm
- 5 Flange without gasket for the compartment door
- 8 Rear insulating barriers (optional except same length terminals)


Tmax XT5 – Installation

Accessories for plug-in circuit-breaker 400A

Rotary handle operating mechanism on the circuit-breaker (RHD)



Drilling templates for support sheet




Tmax XT5 – Installation


Accessories for plug-in circuit-breaker 400A

Flange

- Key
 7 Flange for the compartment door
 8 Compartment door drilling template with/without flange




Drilling template compartment door




	A [mm]	B [mm]	C [mm]	D [mm]
With flange	3p - 4p	147.5	124.3	85.8
Without flange	3p - 4p	140.5	115.3	70.25

Flange IP54


- Key
 10 IP54 flange for the compartment door
 11 Compartment door drilling template with IP54 flange



Compartment door drilling template with flange IP54




Lateral rotary handle operating mechanism on the compartment door (RHL)



Tmax XT5 – Installation

Accessories for plug-in circuit-breaker 400A


Stored energy motor operator (MOE)



Drilling templates for support sheet


Key

- 8 Drilling template 3p
- 9 Drilling template 4p




Flange

—
Key
7 Flange without gasket for the compartment door



Drilling template compartment door

—
Key
6 Compartment door drilling template with/without flange




	A [mm]	B [mm]	C [mm]	D [mm]
With flange 3p - 4p	147.5	124.3	85.8	73.75
Without flange 3p - 4p	140.5	115.3	81.3	70.25

Tmax XT5 – Installation


Accessories for plug-in circuit-breaker 400A

Front for lever operating mechanism (FLD)




Drilling templates for support sheet

- Key
- 1 Fixed part
 - 2 Moving part
 - 3 Tightening torque 2Nm
 - 4 Front for lever operating system (FLD)
 - 5 Phase separators 100mm
 - 7 Flange without gasket for the compartment door
 - 10 Door lock




Flange

- Key
 6 Compartment door drilling template with/without flange
 7 Flange without gasket for the compartment door



Drilling template compartment door




	A [mm]	B [mm]	C [mm]	D [mm]
With flange 3p - 4p	147.5	124.3	85.8	73.75
Without flange 3p - 4p	140.5	115.3	81.3	70.25


Tmax XT5 – Installation

Accessories for plug-in circuit-breaker 400A

Rotary handle operating mechanism on the compartment door (RHE)




Residual current RC



Drilling template for support sheet

- Key
- 1 Fixed part
 - 2 Moving part
 - 3 Tightening torque 2Nm
 - 4 Residual current release
 - 5 Terminal cover for residual current release
 - 8 Fixing on sheet steel




Tmax XT5 – Installation


Accessories for plug-in circuit-breaker 400A

Flange

- Key
 6 Flange for the compartment door
 7 Compartment door drilling template with/without flange



Drilling template compartment door




	A [mm]	B [mm]	C [mm]	D [mm]	E [mm]	F [mm]	G [mm]
With flange	3p - 4p	-	147.5	84.8	-	-	147.5 269.5
Without flange	3p - 4p	163.5	141.5	81.8	101.5	80.3	141.5 -

Tmax XT5 – Installation

Installation for plug-in circuit-breaker 630A


Fixing on sheet

—
Key
 1 Fixed part
 2 Moving part
 3 Tightening torque 2Nm
 4 Phase separators 100mm



Drilling templates for support sheet

—
Key
 7 Drilling template 3p
 8 Drilling template 4p




Tmax XT5 – Installation

Installation for plug-in circuit-breaker 630A


Flange

—
Key
6 Flange without gasket for the compartment door



Drilling template compartment door

—
Key
5 Compartment door drilling template with/without flange




	A [mm]	B [mm]	C [mm]	D [mm]
With flange	3p - 4p	174	152	87
Without flange	3p - 4p	165	143	82.5
				71.5

Tmax XT5 – Installation

Terminals for plug-in circuit-breaker 630A

Terminals EF




Key

- 1 Fixed part
- 2 Moving part
- 3 Tightening torque 2Nm
- 4 Phase separators 100mm

Tmax XT5 – Installation

Terminals for plug-in circuit-breaker 630A



Terminals HR



Key

- 1 Fixed part
- 2 Moving part
- 3 Tightening torque 2Nm

Terminals VR




Key

- 1 Fixed part
- 2 Moving part
- 3 Tightening torque 2Nm

Tmax XT5 – Installation

Accessories for plug-in circuit-breaker 630A


Rotary handle operating mechanism on the circuit-breaker (RHD)



Drilling templates for support sheet


Key

- 8 Drilling template 3p
- 9 Drilling template 4p




Flange

- Key
6 Compartment door drilling template with/without flange
7 Flange for the compartment door




Drilling template compartment door




	A [mm]	B [mm]	C [mm]	D [mm]
With flange	3p - 4p	147.5	124.3	85.8
Without flange	3p - 4p	140.5	115.3	70.25

Flange IP54

- Key
10 IP54 flange for the compartment door
11 Compartment door drilling template with IP54 flange




Drilling template compartment door with flange IP54




Tmax XT5 – Installation

Accessories for plug-in circuit-breaker 630A

Lateral rotary handle operating mechanism on the compartment door (RHL)




Stored energy motor operator (MOE)



- Key
 1 Fixed part
 2 Moving part
 3 Tightening torque 2Nm
 4 Phase separators 100mm
 5 Stored energy motor operator (MOE)

Drilling templates for support sheet




Tmax XT5 – Installation

Accessories for plug-in circuit-breaker 630A


Flange

—
Key
7 Flange without gasket for the compartment door




Drilling template compartment door

—
Key
6 Compartment door drilling template with/without flange




	A [mm]	B [mm]	C [mm]	D [mm]
With flange	3p - 4p	147.5	124.3	85.8
Without flange	3p - 4p	140.5	115.3	70.25

Front for lever operating mechanism (FLD)



Drilling templates for support sheet



Key


- 1 Fixed part
- 2 Moving part
- 3 Tightening torque 2Nm
- 4 Phase separators 100mm
- 5 Front for lever operating mechanism (FLD)
- 6 Compartment door drilling template with/without flang
- 7 Flange without gasket for the compartment door
- 8 Drilling template 3p
- 9 Drilling template 4p
- 10 Door lock

Tmax XT5 – Installation

Accessories for plug-in circuit-breaker 630A


Flange

—
Key
7 Flange without gasket for the compartment door





Drilling template compartment door

—
Key
6 Compartment door drilling template with/without flange



	A [mm]	B [mm]	C [mm]	D [mm]
With flange	3p - 4p 147.5	124.3	85.8	73.75
Without flange	3p - 4p 140.5	115.3	81.3	70.25


Rotary handle operating mechanism on the compartment door (RHE)



Tmax XT5 – Installation


Accessories for plug-in circuit-breaker 630A

Residual current RC




Drilling template for support sheet

- Key
- 1 Fixed part
 - 2 Moving part
 - 3 Tightening torque 2Nm
 - 4 Phase separators 100mm
 - 5 Residual current release
 - 6 Terminal cover for residual current release
 - 9 Fixing on sheet steel




Flange

Key
 7 Flange for the compartment door
 8 Compartment door drilling template with/without flange



Drilling template compartment door




	A [mm]	B [mm]	C [mm]	D [mm]	E [mm]	F [mm]	G [mm]
With flange	3p - 4p	-	147.5	84.8	-	-	147.5 269.5
Without flange	3p - 4p	163.5	141.5	81.8	101.5	80.3	141.5 -

Tmax XT5 – Installation


Installation for withdrawable circuit-breaker 400A

Fixing on sheet




Drilling templates for support sheet


- Key
- 1 Fixed part
 - 2 Moving part
 - 3 Tightening torque 2Nm
 - 4 Front for lever operating mechanism (fld)
 - 5 Phase separators 100mm
 - 8 Drilling template 3p
 - 9 Drilling template 4p
 - 10 Door lock
 - 11 Key lock for fixed part



Flange




Drilling template compartment door



Tmax XT5 – Installation

Terminals for withdrawable circuit-breaker 400A

Terminals EF







—

Key

- 1 Fixed part
- 2 Moving part
- 3 Tightening torque 2Nm
- 4 Front for lever operating mechanism (fld)
- 5 Phase separators 100mm
- 10 Door lock
- 11 Key lock for fixed part

Terminals HR





- Key
- 1 Fixed part
 - 2 Moving part
 - 3 Tightening torque 2Nm
 - 4 Front for lever operating mechanism (FLD)
 - 6 Flange without gasket for compartment door
 - 9 Door lock
 - 10 Terminals for connection
 - 11 Rear insulating barriers (optional except same length terminals)

Tmax XT5 – Installation

Terminals for withdrawable circuit-breaker 400A



Terminals VR



Key

- 1 Fixed part
- 2 Moving part
- 3 Tightening torque 2Nm
- 4 Front for lever operating mechanism (FLD)
- 6 Flange without gasket for compartment door
- 10 Terminals for connection
- 11 Rear insulating barriers (optional except same length terminals)

Residual current (RC) and Front for lever operating mechanism (FLD)




Key
1 Fixed part
2 Moving part
3 Tightening torque 2Nm
4 Front for operating lever mechanism
5 Residual current release
6 Terminal cover for residual current release
7 Flange for the compartment door
8 Flange for residual current release
11 Door lock plate
12 Plug and socket adapter for residual current release


Tmax XT5 – Installation

Terminals for withdrawable circuit-breaker 400A

Drilling template for support sheet Flange



Drilling template compartment door




—
Key

- 7 Flange for the compartment door
- 8 Flange for residual current release
- 9 Compartment door drilling template with/without flange
- 10 Fixing on sheet steel

Tmax XT5 – Installation


Accessories for withdrawable circuit-breaker 400A

Rotary handle operating mechanism on the circuit-breaker (RHD)



Drilling templates for support sheet

Key	
1	Fixed part
2	Moving part
3	Tightening torque 2Nm
4	Rotary handle operating mechanism (RHD)
5	Phase separators 100mm
8	Drilling template 3p
9	Drilling template 4p
10	Door lock




Tmax XT5 – Installation

Accessories for withdrawable circuit-breaker 400A


Flange

—
Key
7 Flange without gasket for the compartment door




Drilling template compartment door

—
Key
6 Compartment door drilling template with flange




Lateral rotary handle operating mechanism on the compartment door (RHL)



Tmax XT5 – Installation


Accessories for withdrawable circuit-breaker 400A

Stored energy motor operator (MOE)




Drilling templates for support sheet


Key	
1	Fixed part
2	Moving part
3	Tightening torque 2Nm
4	Stored energy motor operator (MOE)
5	Phase separators 100mm
8	Drilling template 3p
9	Drilling template 4p



Flange





Drilling template compartment door



Tmax XT5 – Installation

Accessories for withdrawable circuit-breaker 400A

Rotary handle operating mechanism on the compartment door (RHE)




- Key
- 1 Fixed part
 - 2 Moving part
 - 3 Tightening torque 2Nm
 - 4 Phase separators 100mm
 - 5 Rotary handle operating mechanism base (RHE_B)
 - 6 Connection rod (RHE_S)
 - 7 Rotary handle on compartment door (RHE_H)
 - 8 Compartment door drilling template

Tmax XT5 – Installation


Installation for withdrawable circuit-breaker 630A

Fixing on sheet



Drilling templates for support sheet

Key	
1	Fixed part
2	Moving part
3	Tightening torque 2Nm
4	Phase separators 100mm
5	Front for lever operating mechanism
8	Drilling template 3p
9	Drilling template 4p
10	Door lock




Tmax XT5 – Installation

Installation for withdrawable circuit-breaker 630A


Flange

—
Key
7 Flange without gasket for the compartment door



Drilling template compartment door


—
Key
6 Compartment door drilling template with flange



Tmax XT5 – Installation

Terminals for withdrawable circuit-breaker 630A

Terminals EF




—
Key

- 1 Fixed part
- 2 Moving part
- 3 Tightening
torque 2Nm
- 4 Phase separators
100mm
- 5 Front for lever
operating mechanism

Tmax XT5 – Installation

Terminals for withdrawable circuit-breaker 630A


Terminals HR



Key

- 1 Fixed part
- 2 Moving part
- 3 Tightening torque 2Nm
- 4 Front for lever operating mechanism

Terminals VR




—
Key
 1 Fixed part
 2 Moving part
 3 Tightening
 torque 2Nm
 4 Front for lever
 operating
 mechanism (FLD)


Tmax XT5 – Installation

Terminals for withdrawable circuit-breaker 630A


Residual current (RC) and Front for lever operating mechanism (FLD)




- Key**
- 1 Fixed part
 - 2 Moving part
 - 3 Tightening torque 2Nm
 - 4 Front for operating lever mechanism
 - 5 Residual current release
 - 6 Terminal cover for residual current release
 - 7 Flange for the compartment door
 - 8 Flange for residual current release
 - 11 Door lock plate
 - 12 Plug and socket adapter for residual current release




Drilling template for support sheet



Flange



Drilling template compartment door




Key

- 7 Flange for the compartment door
- 8 Flange for residual current release
- 9 Compartment door drilling template with/without flange
- 10 Fixing on sheet steel

Tmax XT5 – Installation


Accessories for withdrawable circuit-breaker 630A

Rotary handle operating mechanism on the circuit-breaker (RHD)




Drilling templates for support sheet

- Key
- 1 Fixed part
 - 2 Moving part
 - 3 Tightening torque 2Nm
 - 4 Phase separators 100mm
 - 5 Rotary handle operating mechanism (RHD)
 - 8 Drilling template 3p
 - 9 Drilling template 4p
 - 10 Door lock




Flange

—
Key
7 Flange without
gasket for the
compartment door



Drilling template compartment door


—
Key
6 Compartment door
drilling template
with flange




Tmax XT5 – Installation

Accessories for withdrawable circuit-breaker 630A

Lateral rotary handle operating mechanism on the compartment door (RHL)




Stored energy motor operator (MOE)



Drilling templates for support sheet

- Key
- 1 Fixed part
- 2 Moving part
- 3 Tightening torque 2Nm
- 4 Phase separators 100mm
- 5 Stored energy motor operator (MOE)
- 8 Drilling template 3p
- 9 Drilling template 4p




Tmax XT5 – Installation

Accessories for withdrawable circuit-breaker 630A


Flange

- Key
7 Flange without gasket for the compartment door




Drilling template compartment door

- Key
6 Compartment door drilling template with flange



Rotary handle operating mechanism on the compartment door (RHE)




Tmax XT6 – Installation

Installation for fixed circuit-breaker

Fixing on sheet


- Key
 1 Front terminals for flat connection
 2 Busbar
 6 Tightening torque 9Nm
 7 Tightening torque 2Nm
 10 Cable rack



A [mm]
With flange 3p - 4p 108
Without flange 3p - 4p 103.5


Drilling templates for support sheet

- Key
 4 Drilling template 3p
 5 Drilling template 4p




Flange

—
Key
3 Flange without
gasket for
compartment door



Drilling template compartment door

—
Key
8 Compartment door
drilling template
with/without flange




	A [mm]	B [mm]	C [mm]	D [mm]	E [mm]
With flange	3p - 4p	108	202	217	88.5
Without flange	3p - 4p	103.5	197	212	86
					106

Tmax XT6 – Installation

Terminals for fixed circuit-breaker

Terminals EF




A [mm]
With flange 3p - 4p 108
Without flange 3p - 4p 103.5

Key

- 1 Extended front terminals
- 5 Tightening torque 9Nm
- 6 Tightening torque 2Nm
- 8 Phase separators 100mm
- 9 High terminal cover with IP40 protection degree
- 11 Cable rack

Terminals ES




Key

- 1 Extended front terminals
- 5 Tightening torque 9Nm
- 6 Tightening torque 2Nm
- 8 Phase separators 200mm
- 10 Cable rack

Tmax XT6 – Installation

Terminals for fixed circuit-breaker


2 x 120...240mm² and 3 x 70...185mm² terminals FC CuAl



Key

- 1 Terminal FCCuAl 630A
- 2 Terminal FCCuAl 800A
- 6 Tightening
torque 9Nm
- 7 Tightening
torque 2Nm
- 9 High terminal
cover with IP40
protection degree
- 10 Tightening
torque 31Nm
- 11 Tightening
torque 43Nm
- 13 Cable rack

Terminals EF and 4 x 70...150mm² terminals FC CuAl (1000A)




- Key**
- 1 Extended front terminals
 - 2 Terminal FCCuAl 1000A
 - 6 Tightening torque 9Nm
 - 7 Tightening torque 2Nm
 - 9 Phase separators 200mm
 - 10 High terminal cover with IP40 protection degree
 - 11 Tightening torque 43Nm
 - 13 Cable rack


Tmax XT6 – Installation

Terminals for fixed circuit-breaker

Terminals R




Terminals HR upper



Key

- 1 Rear terminals
(horizontal or vertical)
- 5 Tightening
torque 18Nm
- 6 Tightening torque 2Nm
- 8 Terminals cover with
IP20 protection degree
(included in the supply
of rear terminals)
- 10 Cable rack

Terminals VR lower




—
Key
3 Drilling template 3p
4 Drilling template 4p
6 Tightening
torque 2Nm


Tmax XT6 – Installation

Accessories for fixed circuit-breaker


Rotary handle operating mechanism on the circuit-breaker (RHD)




Drilling templates for support sheet



Flange



Drilling template compartment door




	A [mm]	B [mm]	C [mm]	D [mm]
With flange	3p - 4p 219	160	89	109.5
Without flange	3p - 4p 209	149.8	83.9	104.5


Tmax XT6 – Installation

Accessories for fixed circuit-breaker

Stored energy motor operator (MOE)



Drilling templates for support sheet




Key

- 1 Circuit-breaker
- 2 Rotary handle operating mechanism on circuit-breaker (RHD)
- 3 Flange for the compartment door
- 5 Fixing on sheet steel III
- 6 Fixing on sheet steel IV
- 7 IP54 flange for the compartment door
- 8 Compartment door sheet steel drilling with IP54 flange


Flange

—
Key
3 Flange for the compartment door



—
Key
4 Compartment door drilling template with/without flange

Drilling template compartment door




	A [mm]	B [mm]	C [mm]	D [mm]
With flange	3p - 4p	219	160	89
Without flange	3p - 4p	209	149.8	83.9
				109.5
				104.5

Tmax XT6 – Installation


Accessories for fixed circuit-breaker

Front for lever operating mechanism (FLD)




Drilling templates for support sheet

- Key
- 1 Circuit-breaker
 - 2 Front for lever operating mechanism (FLD)
 - 3 Flange for the compartment door
 - 5 Fixing on sheet steel III
 - 6 Fixing on sheet steel IV




Flange

- Key
 3 Flange for the compartment door
 4 Compartment door drilling template with / without flange



Drilling template compartment door







	A [mm]	B [mm]	C [mm]	D [mm]
With flange 3p - 4p	219	160	89	109.5
Without flange 3p - 4p	209	149.8	83.9	104.5

Tmax XT6 – Installation

Accessories for fixed circuit-breaker

Rotary handle operating mechanism on the compartment door (RHE)




Key

- 1 Circuit-breaker
- 2 Tightening torque 2Nm
- 3 Base of rotary handle operating mechanism
- 4 Connection rod
- 5 Rotary handle operating mechanism of the compartment door
- 6 Compartment door drilling template

Tmax XT6 – Installation

Installation for withdrawable circuit-breaker


Fixing on sheet



Drilling template for support sheet

Key

- 1 Fixed part
- 2 Moving part
- 3 Extended front terminals
- 5 Drilling template 3p-4p
- 6 Tightening torque 8Nm
- 8 FLD




	A [mm]	B [mm]
3p	140	214
4p	210	284


Tmax XT6 – Installation

Installation for withdrawable circuit-breaker

Flange




Drilling template compartment door



Tmax XT6 – Installation

Terminals for withdrawable circuit-breaker

Terminals EF





—
Key

- 1 Fixed part
- 2 Moving part
- 3 Extended front terminals
- 6 Tightening torque 8Nm
- 8 FLD

Tmax XT6 – Installation


Accessories for withdrawable circuit-breaker

Rotary handle operating mechanism on the circuit-breaker (RHD)



Drilling template for support sheet


- Key
- 1 Fixed part
 - 2 Moving part
 - 3 Extended front terminals
 - 5 Drilling template 3p-4p
 - 6 Tightening torque 8Nm
 - 8 Rotary handle operating mechanism on circuit breaker (RHD)



	A [mm]	B [mm]
3p	140	214
4p	210	284


Flange

—
Key
4 Flange for the compartment door



Drilling template compartment door


—
Key
7 Compartment door drilling template with flange



Tmax XT6 – Installation


Accessories for withdrawable circuit-breaker

Rotary handle operating mechanism on the compartment door (RHE)




Key

- 1 Fixed part
- 2 Moving part
- 3 Extended front terminals
- 4 Tightening torque 2Nm
- 5 Base of rotary handle operating mechanism
- 6 Connection rod
- 7 Rotary handle operating mechanism of the compartment door
- 8 Compartment door drilling template




	A [mm]	B [mm]
3p	140	214
4p	210	284

Stored energy motor operator (MOE)



Drilling template for support sheet




	A [mm]	B [mm]
3p	140	214
4p	210	284


Tmax XT6 – Installation

Accessories for withdrawable circuit-breaker

Flange




Drilling template compartment door




Tmax XT7 – Installation

Installation for fixed circuit-breaker

Fixing on sheet




Drilling templates for support sheet




Key

- 1 Front terminals for flat connection
- 2 Extended front terminals
- 3 Flange for the compartment door
- 4 Flange fixing screws
- 5 Tightening torque 0.5 Nm - 4.4 lbs in
- 6 Drilling template 3p
- 7 Drilling template 4p
- 8 Tightening torque 18 Nm - 159 lbs in
- 9 Key lock
- 10 Padlock device
- 11 Tightening torque 2 Nm - 18 lbs in
- 12 Compartment door drilling template for flange
- 13 Compartment door drilling template for 206x204 frontal
- 14 Clamp for auxiliary contacts

Flange



Compartment door drilling templates




Tmax XT7 – Installation

Terminals for fixed circuit-breaker

Key	
1	Extended front terminals EF
2	Flange for the compartment door
3	Flange fixing screws
4	Tightening torque 0.5 nm - 4.4 lbs in
7	Tightening torque 18 nm - 159 lbs in
8	Key lock
9	Padlock device
10	Tightening torque 2 Nm - 18 lbs in
13	Slot for external signaling
14	Insulating plate
15	Phase separators 100mm
16	High terminal cover with IP40 protection degree



Terminals EF



A [mm]	With standard flange	3p-4p	130÷141
	Without flange	3p-4p	147

Terminals ES


Key	
1	Spreaded extended front terminals ES
2	Flange for the compartment door
3	Flange fixing screws
4	Tightening torque 0.5 nm - 4.4 lbs in
7	Tightening torque 18 nm - 159 lbs in
8	Key lock
9	Padlock device
10	Tightening torque 2 Nm - 18 lbs in
13	Slot for external signaling
14	Insulating plate
15	Phase separators 200mm



4 x 380mm² and 2 x 240mm² FC CuAl

Key


- 1 Fc Cu-Al terminal 4x240mm²
- 2 Fc Cu-Al terminal 2x240mm²
- 3 Flange for the compartment door
- 4 Flange fixing screws
- 5 Tightening torque 0.5 Nm - 4.4 lbs in
- 8 Tightening torque 18 Nm - 159 lbs in
- 9 Tightening torque 43 Nm - 380 lbs in
- 10 Key lock
- 11 Padlock device
- 12 Tightening torque 2 Nm - 18 lbs in
- 15 Slot for external signaling
- 16 Insulating plate
- 17 High terminal cover with IP40 protection degree
- 18 Low protection cover with IP30 protection degree
- 19 Tightening torque 18 Nm - 159 lbs in



Tmax XT7 – Installation

Terminals for fixed circuit-breaker


Terminals HR/VR adjustable




- Key
- 1 HR horizontal rear terminal HR
 - 2 Flange for the compartment door
 - 3 Flange fixing screws
 - 4 Tightening torque 0.5 Nm - 4.4 lbs in
 - 8 Key lock
 - 9 Padlock
 - 10 Slot for external signaling
 - 12 Tightening torque 20 Nm - 177 lbs in
 - 13 Tightening torque 2 Nm - 18 lbs in

	A [mm]
With standard flange	3p-4p 130÷141
Without flange	3p-4p 147


Terminals HR upper



Terminals VR lower




- Key
- 8 Drilling template support plate



	3p	4p
B	70	140
C	192.5	262.5


Terminals HR and VR




- Key
- 1 HR horizontal rear terminal HR
 - 2 VR vertical rear terminal VR
 - 3 Flange for the compartment door
 - 4 Flange fixing screws
 - 5 Tightening torque 0.5Nm - 4.4lbs in
 - 9 Key lock
 - 10 Padlock
 - 11 Clamp for auxiliary contacts
 - 11 Low protection cover with IP30 protection degree
 - 12 Tightening torque 9Nm
 - 8 Drilling template support plate

	A [mm]
With standard flange	3p-4p 130÷141
Without flange	3p-4p 147


Terminals HR upper



Terminals VR lower



- Key
- 8 Drilling template support plate







	3p	4p
B	70	140
C	192.5	262.5



Tmax XT7 – Installation

Accessories for fixed circuit-breaker


Rotary handle operating mechanism on the circuit-breaker (RHD)




Drilling templates for support sheet



Flange




Drilling template compartment door



Key	
1	Circuit-breaker
2	Tightening torque 2Nm
3	Rotary handle operating mechanism for circuit-breaker
4	Plate for door lock
5	Flange without gasket for the compartment door
6	Compartment door drilling template with/without flange
7	Drilling template 3p
8	Drilling template 4p

	A	B	C
With flange	201	116	24.25
Without flange	192	107	19.75

Rotary handle operating mechanism on the compartment door (RHE)




- Key**
- 1 Circuit-breaker
 - 2 Tightening torque
2Nm
 - 3 Base for rotary
handle operating
mechanism
 - 4 500mm
Connection rod
 - 5 Rotary handle
operating
mechanism of the
compartment door
 - 6 Compartment door
drilling template


Tmax XT7 – Installation

Installation for withdrawable circuit-breaker

Fixing on sheet




Drilling templates for support sheet




Key

- 1 EF front terminal
- 2 ES front terminal
- 3 Flange for the compartment door
- 4 Flange fixing screws
- 5 Tightening torque 0.5 Nm - 4.4 lbs in
- 6 Compartment door drilling template for flange
- 7 Fixing on sheet steel drilling template
- 8 Tightening torque 9 Nm - 79.6 lbs in
- 9 Mounting at wall
- 10 Keylock
- 11 Padlock
- 12 Clamp for auxiliary contacts
- 13 Tightening torque 9 Nm - 79.6 lbs in

Flange




Drilling template compartment door



Tmax XT7 – Installation

Terminals for withdrawable circuit-breaker

Terminals EF and ES




Key

- 1 EF front terminal
- 2 ES front terminal
- 4 Flange fixing screws
- 5 Tightening torque
0.5 Nm - 4.4 lbs in
- 8 Tightening torque
9 Nm - 79.6 lbs in
- 10 Key lock
- 11 Padlock
- 12 Clamp for auxiliary contacts
- 13 Tightening torque
9 Nm - 79.6 lbs in


Tmax XT7 – Installation

Terminals for withdrawable circuit-breaker


Terminals R




Terminals VR upper




Terminals HR lower




- Key**
- 1 HR horizontal rear terminal HR
 - 2 VR vertical rear terminal VR
 - 3 Flange for the compartment door
 - 4 Flange fixing screws
 - 5 Tightening torque 0.5 Nm - 4.4 lbs in
 - 8 Tightening torque 9 Nm - 79.6 lbs in
 - 9 Mounting at wall
 - 10 Key lock
 - 11 Padlock
 - 12 Slot for external signaling
 - 13 Tightening torque 9 Nm - 79.6 lbs in




Terminals SHR



Terminals VR upper




Terminals HR lower



Key






- 1 SHR rear side terminals (3p)
- 2 SHR rear side terminals (4p)
- 3 Flange for the compartment door
- 4 Flange fixing screws
- 5 Tightening torque 0.5 Nm - 4.4 lbs in
- 8 Tightening torque 9 Nm - 79.6 lbs in
- 9 Mounting at wall
- 10 Key lock
- 11 Padlock
- 12 Slot for external signaling
- 13 Tightening torque 9 Nm - 79.6 lbs in





Tmax XT7 – Installation

Accessories for withdrawable circuit-breaker

Rotary handle operating mechanism on the circuit-breaker (RHD)




Drilling templates for support sheet




- Key**
- 1 Moving part
 - 2 Fixed part
 - 3 Rotary handle operating mechanism for circuit-breaker
 - 4 Flange for the compartment door
 - 5 Compartment door drilling template for flange
 - 6 Mounting at wall
 - 7 Fixing on sheet steel drilling template


Flange



Drilling template compartment door



Rotary handle operating mechanism on the compartment door (RHE)




Key

- 1 Circuit-breaker
- 2 Fixed part
- 3 Base for rotary handle operating mechanism
- 4 500mm Connection rod
- 5 Rotary handle operating mechanism of the compartment door
- 6 Compartment door drilling template


Tmax XT7 M – Installation

Installation for fixed circuit-breaker

Fixing on sheet




Drilling templates for support sheet




- Key
- 1 Front terminals for flat connection
 - 2 Extended front terminals
 - 3 Flange for the compartment door
 - 4 Flange fixing screws
 - 5 Tightening torque 0.5 Nm - 4.4 lbs in
 - 6 Drilling template 3p
 - 7 Drilling template 4p
 - 8 Tightening torque 18 Nm - 159 lbs in
 - 9 Key lock
 - 10 Tightening torque 2 Nm - 18 lbs in
 - 11 Compartment door drilling template for flange
 - 12 Compartment door drilling template for 206x204 frontal
 - 13 Clamp for auxiliary contacts

Flange



Compartment door drilling templates




Tmax XT7 M – Installation

Terminals for fixed circuit-breaker

Terminals EF

Key

- 1 Extended front terminals EF
- 2 Flange for the compartment door
- 3 Flange fixing screws
- 4 Tightening torque 0,5 Nm - 4,4 lbs in
- 7 Tightening torque 18 Nm - 159 lbs in
- 8 Key lock
- 9 Tightening torque 2Nm - 18 lbs in
- 12 Slot for external signaling
- 13 Insulating plate
- 14 Phase separators 100mm
- 15 High terminal cover with IP40 protection degree




	A [mm]
With standard flange	3p-4p 130÷141
Without flange	3p-4p 147

Terminals ES

Key

- 1 Spreaded extended front terminals ES
- 2 Flange for the compartment door
- 3 Flange fixing screws
- 4 Tightening torque 0,5 Nm - 4,4 lbs in
- 7 Tightening torque 18 Nm - 159 lbs in
- 8 Key lock
- 9 Tightening torque 2Nm - 18 lbs in
- 12 Slot for external signaling
- 13 Insulating plate




Tmax XT7 M – Installation


Terminals for fixed circuit-breaker

4 x 380mm² and 2 x 240mm² FC CuAl

Key	
1	Fc Cu-Al terminal 4x240mm ²
2	Fc Cu-Al terminal 2x240mm ²
3	Flange for the compartment door
4	Flange fixing screws
5	Tightening torque 0.5 Nm - 4.4 lbs in
8	Tightening torque 18 Nm - 159 lbs in
9	Tightening torque Nm - 380 lbs in
10	Key lock
11	Tightening torque 2 Nm - 18 lbs in
14	Slot for external signaling
15	Insulating plate
16	High terminal cover with IP40 protection degree
17	Low protection cover with IP30 protection degree
18	Tightening torque 18 Nm - 159 lbs in




Terminals HR/VR adjustable




Key

- 1 HR horizontal rear terminal HR
- 2 Flange for the compartment door
- 3 Flange fixing screws
- 4 Tightening torque
0.5 Nm - 4.4 lbs in
- 8 Key lock
- 9 Padlock
- 10 Slot for external signaling
- 11 Tightening torque
20 Nm - 177 lbs in

Terminals HR upper




Terminals VR lower



Key

- 8 Drilling template support plate




	3p	4p
B	70	140
C	192.5	262.5

Tmax XT7 M – Installation

Terminals for fixed circuit-breaker


Terminals HR and VR




	A [mm]
With standard flange	3p-4p 130÷141
Without flange	3p-4p 147

Key
 1 HR horizontal rear terminal HR
 2 VR vertical rear terminal VR
 3 Flange for the compartment door
 4 Flange fixing screws
 5 Tightening torque 0.5Nm - 4.4lbs in
 9 Key lock
 10 Clamp for auxiliary contacts
 11 Low protection cover with IP30 protection degree
 12 Tightening torque 9Nm


Terminals HR upper



Terminals VR lower



Key
 8 Drilling template support plate




	3p	4p
B	70	140
C	192.5	262.5


Tmax XT7 M – Installation

Installation for withdrawable circuit-breaker

Fixing on sheet




Drilling template for support sheet




— Key

- 3 Flange for the compartment door
- 6 Compartment door drilling template for flange
- 7 Fixing on sheet steel drilling template
- 10 Key lock
- 11 Padlock

Flange




Drilling template compartment door




Tmax XT7 M – Installation

Terminals for withdrawable circuit-breaker


Terminals R




Terminals VR lower



Terminals HR lower




- Key
- 1 HR horizontal rear terminal HR
 - 2 VR vertical rear terminal VR
 - 3 Flange for the compartment door
 - 4 Flange fixing screws
 - 5 Tightening torque 0.5 Nm - 4.4 lbs in
 - 8 Tightening torque 9 Nm - 79.6 lbs in
 - 9 Mounting at wall
 - 10 Key lock
 - 11 Padlock
 - 12 Slot for external signaling
 - 13 Tightening torque 9 Nm - 79.6 lbs in



Tmax XT – Common accessories

Horizontal interlock XT series




	B	C
XT1	104.25	129.25
XT2	101.75	131.75
XT3	99.75	133.75
XT4	99.25	134.25


Tmax XT – Common accessories

Horizontal interlock XT series

Horizontal interlock between two circuit breakers (MIR-H)




Drilling template




- Key
- 1 Interlocking mechanism
 - 2 Drilling template for fixing interlocking system
 - 3 Drilling template for all version with rear terminals
 - 4 Tightening torque 3,7Nm
 - 5 Tightening torque 3Nm
 - 6 Tightening torque 2,5Nm
 - 7 Interlocking plate for circuit-breakers
 - 8 Provision for 4p circuit-breaker
 - 9 Dimension for XT4 circuit-breaker only
 - 10 A = 23mm XT4 withdrawable with key lock for fixed part
A = 28,5mm XT5 withdrawable with key lock for fixed part
 - 11 Hole for front mounting only
 - 12 Hole for rear mounting only

Interlocking plate



Type	Description	B	C
Plate A	XT4 F	79.75	152.25
Plate B	XT4 P/W	79.75	152.25
Plate C	XT5 F	96.75	135.25
Plate D	XT5 400 P/W	96.75	135.25
Plate E	XT5 630 P/W	96.75	135.25

Horizontal interlock between two circuit breakers (MIR-H)




- Key**
- 1 Interlocking mechanism
 - 2 Drilling template for fixing interlocking system
 - 3 Drilling template for all version with rear terminals
 - 4 Tightening torque 18Nm
 - 5 Tightening torque 3Nm
 - 6 Tightening torque 3Nm
 - 7 Interlocking plate for circuit-breakers
 - 8 Provision for 4p circuit-breaker


Tmax XT – Common accessories

Horizontal interlock XT series

Drilling template



Interlocking plate






Key
 9 - 4xØ9-M8 hole for front mounting only
 10 - 4xØ9 hole for rear mounting only

Coupling plate type	A	B	C
MIR-P XT5 F	13.25	102.9	232.1
MIR-P XT5 P/W 400	13.25	102.9	232.1
MIR-P XT5 P/W 630	13.25	102.9	232.1
MIR-P XT6 F	0	137.5	197.5
MIR-P XT6 W	0	137.5	197.5

Tmax XT – Common accessories

Vertical interlock XT series



—

Key

- 1 Interlock device
- 2 Drilling template for fixing the interlock device on sheet Steel
- 3 Drilling template for all rear terminal version
- 4 Tightening torque 9Nm
- 6 Tightening torque 1Nm
- 7 Tightening torque under customer's responsibility
- 9 Provision for 4p circuit-breaker
- 10 A=35mm for XT4 fixed part
Withdrawable with padlock device
A=30mm for XT2 fixed part
Withdrawable with padlock device

—


Note:

For the overall dimensions of the circuit-breaker see the relevant dimension tables and the configuration

Tmax XT – Common accessories

Vertical interlock XT series


Vertical interlock between two circuit breakers (MIR-V)




Key

- 1 Interlocking mechanism
- 4 Tightening torque 3,7Nm
- 5 Tightening torque 3Nm
- 6 Tightening torque 2,5Nm
- 7 Interlocking plate for circuit-breakers
- 8 Provision for 4p circuit-breaker
- 9 A = 26mm XT4 withdrawable with key lock for fixed part
A = 29,5mm XT5 withdrawable with key lock for fixed part

Drilling template



Interlocking plate




- Key
- 2 Drilling template for fixing interlocking system
 - 3 Drilling template for all version with rear terminals
 - 10 Hole for front mounting only
 - 11 Hole for rear mounting only

Type	Description	B
Plate A	XT4 F	40.25
Plate B	XT4 P/W	40.25
Plate C	XT5 F	23.25
Plate D	XT5 400 P/W	23.25
Plate E	XT5 630 P/W	23.25

Tmax XT – Common accessories

Vertical interlock XT series

Vertical interlock between two circuit breakers (MIR-V)




—


Key

- 1 Interlocking mechanism
- 2 Tightening torque 18Nm
- 3 Tightening torque 3Nm
- 4 Tightening torque 3Nm
- 5 Tightening torque 3Nm
- 6 Tightening torque 3Nm
- 7 Interlocking plate for circuit-breakers
- 8 Pre-drilling for 4P version

Drilling template



Interlocking plate

**Key**

- 2 Drilling template for fixing interlocking system
- 3 Drilling template for all version with rear terminals
- 9 $4 \times \varnothing 9 - M8$ hole for front mounting only
- 10 $4 \times \varnothing 9$ hole for rear mounting only

Coupling plate type	A	B	C
MIR-P XT5 F	67.1	210.75	237.25
MIR-P XT5 P/W 400	67.1	210.75	237.25
MIR-P XT5 P/W 630	67.1	210.75	237.25
MIR-P XT6 F	32.5	224	224
MIR-P XT6 W	32.5	224	224


Wiring diagrams

Reading information

- 3/2** Graphical symbols for electrical diagrams (617 IEC STANDARDS)
3/4 Information on how to read the diagrams

Wiring diagrams

- 3/13** Diagrams for XT1...XT4
3/17 Diagrams for XT5-XT6
3/35 Diagrams for XT7 and XT7 M
3/60 XT2-XT4-XT5-XT7-XT7 M modules

































To access the full set of wiring diagrams in ABB Library scan the QR code or enter through the following link: to.abb/Z4hPKw-D

Reading information

Graphical symbols for electrical diagrams (60617 IEC STANDARDS)

Graphical symbols for electrical diagrams (Standards IEC 60617)

	Thermal effect		Conductors with corded cables (example two conductors)		Three-phase asynchronous motor, with short-circuited rotor (cage)
	Electromagnetic effect		Key operating mechanism		Current transformer
	Timing		Cam operating mechanism		Current transformer with primary consisting of 4 passing conductors and with wound secondary, with socket
	Mechanical connection		Ground (general symbol)		Closing contact
	Manual mechanical operating mechanism (general case)		Connection of conductors		Voltmeter
	Rotary handle operating mechanism		Terminal or clamp		Opening contact
	Pushbutton operating mechanism		Socket and plug (female and male)		Changeover contact with momentary break
	Converter separated galvanically		Resistor (general symbol)		Closing position contact (limit switch)
	Conductors in shielded cable (example two conductors)		Resistor dependent on the temperature		Opening position contact (limit switch)
	Watt-hour meter		Motor (general symbol)		Changeover contact with momentary break (limit switch)

	Contactor (closing contact)		Overcurrent release with long inverse adjustable time delay characteristic		Brush
	Power cut-off of switch- disconnector power with automatic opening		Overcurrent release for earth fault with short inverse time characteristic		Wattmeter
	Switch-disconnector		Current relay for unbalance between phases		Screen, shield (it may be drawn in any convenient shape)
	Control coil (general symbol)		Residual current release		Ideal current source
	Thermal trip unit		Relay for detecting lack of phase in a three-phase system		Three connections
	Instantaneous overcurrent release		Relay for detecting blocked rotor by means of current measurement		Voltage transformer
	Ammeter		Lamp, general symbol		Winding of three-phase transformer, connection star
	Overcurrent release with short adjustable time delay characteristic		Motor with excitation in series		Primary cell, secondary cell, battery of primary cell or secondary cell
	Overcurrent release with short inverse adjustable time delay characteristic				

Reading information

Information on how to read the diagrams

State of operation shown

The diagrams are shown in the following conditions:

- fixed version circuit-breaker, open;
- withdrawable or plug-in version circuit-breaker, open and connected;
- contactor for starting the motor open;
- circuits de-energised;
- trip units not tripped;
- motor operator with springs charged.

Key XT1...XT4

*	= See note indicated by the letter	K	= Motor starting contactor
A12	= Ekip Com type interface unit	K51	= Ekip type electronic relay for overcurrent protection
A13	= Ekip Signaling 10K type signaling unit	K51/CI	= Motor starting contactor operator module
A14	= MOE-E type stored energy motor operator actuating unit	K51/COM	= Communication module
A15	= Ekip Multimeter type measurement unit	K51/MEAS	= Measurement module
A16	= Ekip Micro Module I/O type interface unit	K51/SIGN	= Signaling module
A17	= MOE type stored energy motor operator actuating unit	K51/SUPPLY	= Auxiliary supply module (110-240VAC/DC and 24-48VDC)
BUS1	= Serial interface with external bus	K51/SYNC	= Synchronizing module
BUS2	= Redundant serial interface with external bus	K51/TEMP	= Temperature monitoring module
LINK BUS	= Interface with external Link bus	K87	= Residual current relay
	D 2 Electronic time-delay device for undervoltage release coil YU, outside circuit-breaker (only for voltage up to 250 V)	M	= Motor with energizing in series for circuit-breaker opening and closing (Fig. 21)
H2	= Signaling lamp for stored energy motor operator blocked	M	= Motor for opening circuit-breaker and loading the closing springs (Fig. 22-54-55-56-57)
I 11...32	= Programmable digital inputs	M1	= Three-phase asynchronous motor
41...43 51...53	= Analog inputs from temperature sensor	0 11...32	= Programmable signaling contacts
44-54	= Analog inputs from 4-20mA sensor	OCI	= Contact for motor starting contactor operating mechanism
Pt1OO	= Analog input from Pt1OO temperature sensor of motor	0 SC	= Synchronism monitoring contact
I reset	= Digital input for resetting tripped motor starting contactor operating unit	Q	= Main circuit-breaker
J...	= Connectors for auxiliary circuits of withdrawable circuit-breaker. Withdrawal of connectors occurs at the same time as that of circuit-breaker	Q/O...7	= Auxiliary contacts of the circuit-breaker open/closed
		R-R1	= Resistor
		R2	= Pt100 temperature sensor of motor
		81	= Contact controlled by the motor operator cam
		82	= Contact controlled by the key lock of the direct action motor operator
		83/1-2	= Contacts operated by Auto/Manual selector switch and by key lock of the stored energy motor operator
		S4	= Contact operated by direct action motor operator cam
		S4/1-2	= Early auxiliary contacts operated by circuit-breaker mounted crank handle
		851	= Contact for signaling circuit-breaker open due to tripped thermomagnetic overcurrent protection release or electronic relay

86/1-2	= Contacts controlled by Auto/Manual selector switch of direct action motor operator	W2	= Serial interface with internal bus (local bus)
S75E/1-2	= Contacts for signaling circuit-breaker in withdrawn position (only applicable to withdrawable circuit-breaker versions)	W9...14	= Connector RJ45 for interface unit and for communication modules
S75I/1-2-5	= Contacts for signaling circuit-breaker in racked-in position (only applicable to withdrawable or plug-in circuit-breaker versions)	W9R...12R	= Connector RJ45 for redundant communication modules
S87/1	= Contact for electrical signaling of residual current relay prealarm	X3-X4-X8	= Protection relay connectors
S87/2	= Contact for electrical signaling of residual current relay alarm	X41	= Connector of current circuit for external neutral
S87/3	= Contact for electrical signaling of circuit-breaker open due to residual current relay trip	XB..	= Three-way connector for auxiliary circuits of plug-in circuit-breaker
SC	= Pushbutton or contact for closing the circuit-breaker	XC..	= Six-way connector for auxiliary circuits of plug-in circuit-breaker
SC3	= Motor start pushbutton	XC2-3	= Six-way connector for auxiliary circuits of plug-in circuit-breaker for voltage up to 400V
SD	= Residual current relay supply disconnect	XCT1-2	= Terminal box of Ekip DIN Rail Cartridge Basic or Ekip DIN Rail Cartridge
SO	= Pushbutton or contact for opening circuit-breaker	XD..	= Nine-way connector for auxiliary circuits of plug-in circuit-breaker
SO3	= Motor stop pushbutton	XE..	= Fifteen-way connector for auxiliary circuits of plug-in circuit-breaker
SR	= Electrical reset pushbutton or contact	XF..	= Ekip Com type interface unit connector
SY/1...3	= Contacts for signaling circuit-breaker open due to tripped overcurrent protection relay, thermomagnetic release and coils Y0, YO1, Y02, YU (trip position)	XG	= Protection relay connector
TI	= Toroidal current transformer	XH1	= Protection relay connector
TI/L1-L2-L3	= L1-L2-L3 phase current transformer	XK7	= Connector of contact S75I/5
TI/N	= Current transformer on neutral	XM	= MOE-E actuator unit connector
TU2	= Insulation voltage transformer (outside circuit-breaker)	XV	= Terminal box of circuit-breaker applications
Uaux	= Auxiliary supply voltage	YC	= Closing coil of stored energy motor operator
V1	= Circuit-breaker applications	YO	= Opening coil
V2	= Motor operator applications	YO1	= Coil for opening due to overcurrent
V4	= Indicative switchgear and connections for operation and signaling, outside circuit-breaker	YO2	= Opening coil of residual current relay
V5	= Ekip DIN Rail Cartridge Basic or Ekip DIN Rail Cartridge applications	YU	= Undervoltage coil

Reading information

Information on how to read the diagrams

Notes XT1...XT4

- A) The presence of an auxiliary supply is required for the local bus and zone selectivity functions (see Fig. 51-81).
- B) The undervoltage coil is provided for power supply branched on the supply side of the circuit-breaker or from an independent source: circuit-breaker can only close when coil is energized (closing lock is obtained mechanically).
- C) Contacts 84/1 and 84/2 of Fig. 7-8 open circuit when circuit-breaker is open and close it again when a manual closing command is imparted by means of the rotary handle, in accordance with the Standards governing machine tools (however, circuit-breaker will not close if undervoltage release is not being supplied).
- E) If the application in Fig. 21 and the contacts in Fig. 31 must be installed at the same time, contact 0/2 must be installed in the adjacent slot (marked 0/1).
- F) R= Additional external undervoltage resistor supplied at 380/440 VAC and 480/525 VAC.
R1= Additional external resistor for stored energy motor operator or direct action motor operator supplied at 480/525VAC.
- G) If a three-pole fixed circuit-breaker with current transformer on the neutral conductor outside the circuit-breaker is used, the terminals of the TI/N transformer must be short-circuited when the circuit-breaker must be removed.
- H) "Galvanically separated converters" conforming to standards IEC 60950 (UL 1950) or equivalent must be used since an earthed Uaux is required.
- I) Mandatory in the presence of any sort of Ekip module.
- L) Only one application among Fig. 83...97-131-132 can be supplied in the case of Ekip DIN Rail Cartridge Basic. In the case of Ekip DIN Rail Cartridge, up to three applications can be supplied among Fig. 83...97-131-132, taken once only. In addition, the Ekip Com module (if chosen) can be duplicated by choosing among Fig. 110...116.
- M) To ensure correct operation, at least one module must always be present.
- N) BELDEN 3105A cables or an equivalent type must be used.
- O) When there are several Ekip Com modules with withdrawable circuit-breakers, contact S75I/5 must be connected once only to one single module.
- P) Auxiliary voltage Uaux allows all the functions of EKIP electronic protection relays to be activated. "Galvanically separated converters" conforming to standards IEC 60950 (UL 1950) or equivalent must be used since an earthed Uaux is required.
- Q) BELDEN 3105A cables or an equivalent type must be used. Maximum length 15 m.
- R) Recommended RJ45 cable: CAT6 STP.
- S) Consult "Technical Application Papers - vol. 9: Communication via BUS with ABB circuit-breakers" for connection of the EIA RS485 serial line.
- T) Short-circuit terminals 1200 on to install a termination resistor on the Local Bus.
- U) Use Belden 3079A cables or equivalent. Consult White Paper 1SDCOO741ZGO201 "Communication with SACE Emax 2 circuit-breakers" for further details.
- V) Use Belden 3084A cables or equivalent. Consult White Paper 1SDC007412G0201 "Communication with SACE Emax 2 circuit-breakers" for further details.
- Z) Ekip Supply cannot be used to energize the electronic relay via terminals K1 and K2.
- AA) Consult Fig. 51 or 81 for the connection of W3 and W4.
- AB) Use two-pole shielded cable type BELDEN 8762/8772 or equivalent. The shield must be earthed on the selectivity input side (for zone selectivity) or on both sides (for other applications).
- AC) The rated maximum secondary voltage is 120V.
- AD) Use insulated cables for thermocouples such as PENTRONIC TEC/SITW-24F (Type TX) or equivalent. Maximum length 3 m.
- AE) Use suitable cables up to 3 meters in length compatible with the workplace in which the 4-20mA current sensor is used.

Key XT5-XT6

*	= See note indicated by the letter
A12	= Ekip Com type Interface unit
A13	= Ekip Signaling 10K type signaling unit
A14	= MOE-E type stored energy motor operator actuating unit
A15	= Ekip Multimeter type measurement unit
A16	= Ekip Micro Module I/O type interface unit
A17	= MOE type stored energy motor operator actuating unit
A18	= Ekip DIN Rail Cartridge Basic
A19	= Ekip DIN Rail Cartridge
BUS1	= Serial interface with external bus
BUS2	= Redundant serial interface with external bus
LINK BUS	= Interface with external Link bus
D	= Electronic time delay device for undervoltage release coil YU, outside circuit-breaker (only for voltages up to 250V)
H2	= Signaling lamp for stored energy motor operator blocked
I 01-11...32	= Programmable digital inputs
I 41-51	= Analog inputs from 4-20mA sensor
I 42-44 52...54	= Analog inputs temperature sensor
I Pt 100	= Analog input from Pt 100 temperature sensor of motor
I reset	= Digital input for resetting tripped motor startin contactor operating unit
J...	= Connectors for auxiliary circuits of a withdrawable circuit-breaker. Withdrawal of connectors occurs at the same time as that of circuit-breaker
K	= Motor starting contactor
K51	= Ekip type electronic relay for overcurrent protection
K51/Cl	= Motor starting contactor operator module
K51/COM	= Communication module
K51/SIGN	= Signaling module
K51/SUPPLY	= Auxiliary supply module (110-240VAC/DC and 24-48Vdc)
K51/SYNC	= Synchronizing module

K51/TEMP	= Temperature monitoring
K87	= Residual current release type RC Inst, RC Sel, RC Sel 200, RC B Type
KO	= Auxiliary opening relay
M	= Motor for opening circuit-breaker and loading closing springs
O 01-11...32	= Programmable signaling contacts
OCI	= Contact for motor starting contactor operating mechanism
O SC	= Synchronism monitoring contact
Q	= Main circuit-breaker
Q/0..7	= Auxiliary contacts of the circuit-breaker open/closed
Q/26	= Open/Close auxiliary used internally by protection release
R	= Resistor
R2	= Pt100 temperature sensor of motor
S1	= Contact controlled by the motor operator cam
S3/1-2	= Contacts controlled by Auto/Manual selector switch and key lock of motor
S4/1-2	= Early auxiliary contacts
S4/1-4	= Early auxiliary contacts operated by circuit-breaker mounted crank handle
S51	= Contact for signaling circuit-breaker open due to tripped thermomagnetic overcurrent protection release or electronic relay
S52	= YU/YO trip signaling contact (for voltage up to 250V)
S75E/1	= Contact for signaling circuit-breaker in racked out position (only applicable to withdrawable circuit-breaker versions)
S75E/1-2-3	= Contacts for signaling circuit-breaker in racked-in position (only applicable to withdrawable or plug-in circuit-breaker versions)
S75T/1	= Contact for signaling circuit-breaker in test position (only applicable to withdrawable circuit-breaker versions)
S87/1	= Contact for electrical signaling of residual current relay prealarm
S87/2	= Contact for electrical signaling of residual current relay alarm

Reading information

Information on how to read the diagrams

S87/3	= Contact for electrical signaling of circuit-breaker open due to residual current relay trip	XCT1-2	= Terminal box of Ekip DIN Rail Cartridge Basic or Ekip DIN Rail Cartridge
SC	= Pushbutton or contact for closing the circuit-breaker	XD..	= Nine-way connector for auxiliary circuits of plug-in circuit-breaker
SC3	= Motor start pushbutton	XE..	= Fifteen-way connector for auxiliary circuits of plug-in circuit-breaker
SD	= Residual current relay supply disconnector	XF..	= Ekip Corn type interface unit connector
SO	= Pushbutton or contact for opening circuit-breaker	XH1	= Protection relay connector
S03	= Motor stop pushbutton	XV	= Terminal box of circuit-breaker applications
SR	= Electrical reset pushbutton or contact	YC	= Closing coil of stored energy motor operator
SY/1...3	= Contacts for signaling circuit-breaker open due to tripped overcurrent protection relay, thermomagnetic release and coils YO, Y01, Y02, YU (tripped position)	YO	= Opening coil
TI	= Toroidal current transformer	YO1	= Coil for opening due to overcurrent
TI/L1-L2-L3	= L1-L2-L3 phase current transformer	YO2	= Opening coil of residual current relay
TI/N	= Current transformer on neutral	YU	= Undervoltage coil
TU2	= Insulation voltage transformer (out side circuit-breaker)	YU/0	= Undervoltage and opening coil (Combo)
Uaux	= Auxiliary supply voltage		
V1	= Circuit-breaker applications		
V2	= Motor operator applications		
V4	= Indicative switchgear and connections for operation and signaling, outside circuit-breaker		
V5	= Ekip DIN Rail Cartridge Basic or Ekip DIN Rail Cartridge applications		
W2	= Serial interface with internal bus (local bus)		
W9...14	= Connector RJ45 for interface unit and for communication modules		
W9R...12R	= Connector RJ45 for redundant communication modules		
X3-X4-X8	= Protection relay connectors		
XB..	= Three-way connector for auxiliary circuits of plug-in circuit-breaker		
XC..	= Six-way connector for auxiliary circuits of plug-in circuit-breaker		
XC2-3	= Six-way connector for auxiliary circuits of plug-in circuit-breaker for voltage up to 400V		

Notes XT5-XT6

- A) The presence of an auxiliary supply is required for the local bus and zone selectivity functions (see Fig. 41-78).
- B) The undervoltage coil is provided for power supply branched on the supply side of the circuit-breaker or from an independent source: circuit-breaker can only close when coil is energized (closing lock is obtained mechanically).
- C) Contacts S4/1 and S4/2 of Fig. 7-10-15 open circuit when circuit-breaker is open and close it again when a manual closing command is imparted by means of the rotary handle, in accordance with the Standards governing machine tools (however, circuit-breaker will not close if undervoltage release is not being supplied).
- D) Only for XT5 F-P.
- E) Only for XT5.
- G) If a three-pole fixed circuit-breaker with current transformer on the neutral conductor outside the circuit-breaker is used, the terminals of the TI/N transformer must be short-circuited when the circuit-breaker must be removed.
- H) "Galvanically separated converters" conforming to standards IEC 60950 (UL 1950) or equivalent must be used since an earthed Uaux is required.
- I) Mandatory in the presence of any sort of Ekip module.
- L) Only one application among Fig. 79...93-131-132 can be supplied in the case of Ekip DIN Rail Cartridge Basic. In the case of Ekip DIN Rail Cartridge, up to three applications can be supplied among Fig. 79...93-131-132, taken once only. In addition, the Ekip Com module (if chosen) can be duplicated by choosing among Fig. 110...116.
- M) To ensure correct operation, the Ekip Supply module and at least one module must always be present.
- N) BELDEN 3105A cables or an equivalent type must be used.
- O) When there are several Ekip Com modules with withdrawable circuit-breakers, contact 5751/2 must be connected once only to one single module.
- P) Auxiliary voltage Uaux allows all the functions of EKIP electronic protection relays to be activated. "Galvanically separated converters" conforming to standards IEC 60950 (UL 1950) or equivalent must be used since an earthed Uaux is required.
- Q) BELDEN 3105A cables or an equivalent type must be used. Maximum length 15 m.
- R) Recommended RJ45 cable: CAT6 STP.
- S) Consult "Technical Application Papers - vol. 9: Communication via BUS with ABB circuit-breakers" for connection of the EIA RS485 serial line.
- T) Short-circuit terminals 1200 on to install a termination resistor on the Local Bus.
- U) Use Belden 3079A cables or equivalent. Consult White Paper 1SDC007412G0201 "Communication with SACE Emax 2 circuit-breakers" for further details.
- V) Use Belden 3084A cables or equivalent. Consult White Paper 1SDC007412G0201 "Communication with SACE Emax 2 circuit-breakers" for further details.
- Z) Ekip Supply cannot be used to energize the electronic relay via terminals K1 and K2.
- AA) Consult Fig. 78 for the connection of W3 and W4.
- AB) Use two-pole shielded cable type BELDEN 8762/8772 or equivalent. The shield must be earthed on the selectivity input side (for zone selectivity) or on both sides (for other applications).
- AC) The rated maximum secondary voltage is 120V.
- AD) Use insulated cables for thermocouples such as PENTRONIC TEC/SITW-24F (Type TX) or equivalent. Maximum length 3 m.
- AE) Use suitable cables up to 3 meters in length compatible with the workplace in which the 4-20mA current sensor is used
- AG) Relay type TMG for XT5 only
- AH) Designation Connector X .. -> X3 for XT5; X4 for XT6

Reading information

Information on how to read the diagrams

Key XT7-XT7M

*	= See note indicated by the letter
A1	= Applications located on the moving part of the circuit-breaker
A3	= Applications located on the fixed part of the circuit-breaker
A4	= Indicative devices and connections for control and signaling, outside the circuit-breaker
A13	= Signaling unit type Ekip Signalling 10K
A15	= Metering unit type Ekip Multimeter
BUS1	= Serial interface with external bus
BUS2	= Redundant serial interface with external bus
LINK BUS	= Interface with the external Link bus
D	= Electronic time-lag device of YU under voltage coil, outside the circuit-breaker
GZi(DBi)	= Zone selectivity input for G protection or input in "reverse" direction for D protection
GZo(DBo)	= Zone selectivity output for G protection or output in "reverse" direction for D protection
11...32	= Programmable digital inputs
41...43 51...53	= Analogue inputs from temperature sensor
44-54	= Analogue inputs from 4-20mA sensor
K51	= Ekip type electronic release for overcurrent protection
K51/COM	= Communication module
K51/MEAS	= Measurement module
K51/SIGN	= Signaling module
K51/SUPPLY	= Auxiliary supply module (110-220VAC/DC and 24-48VDC)
K51/SYNC	= Synchronization module
K51/TEMP	= Temperature monitoring module
K51/YC	= Closing command from EKIP protection release
K51/YO	= Opening command from EKIP protection release
M	= Motor for loading closing springs
O 11...32	= Programmable signaling contacts
O SC	= Contact for synchronism control
Q	= Circuit-breaker

Q/1...25	= Open/close auxiliary contacts of circuit-breaker
Q/26-27	= Open/close auxiliary contacts used internally by protection release
RC	= RC (residual current) protection sensor
RTC EKIP	= Ready to close auxiliary contact of circuit-breaker, used internally by protection release
RTC	= Contact for signaling circuit-breaker is ready to close
S4/1-2	= Early auxiliary contacts (AUE1-2)
S33M/1-2	= Limit contacts of spring loading motor
S43	= Switch for presetting remote/local control
S51	= Contact for signaling circuit breaker open due to tripping of overcurrent protection release
S52	= Contact for signaling circuit breaker open due to tripping of opening coil and of undervoltage coil
S75E/1-2	= Contacts for signaling circuit-breaker in racked-out position (only provided with withdrawable circuit-breakers)
S75I/1-2-5	= Contacts for signaling circuit-breaker in racked-in position (only provided with withdrawable circuit-breakers)
S75T/1-2	= Contact for signaling circuit-breaker in test position (only provided with withdrawable circuit-breakers)
SC	= Pushbutton or contact for closing circuit-breaker
S0	= Pushbutton or contact for immediate opening of circuit-breaker
S01	= Pushbutton or contact for opening circuit-breaker with time-delayed trip
SR	= Pushbutton or contact for electrical resetting of S51 trip contact
SY	= Contact for signaling circuit breaker open due to tripping of overcurrent protection release and of Y0, Y02, YU coils (tripped position)
SZi(DFi)	= Zone selectivity input for S protection or input in "forward" direction for S protection

SZo(DFo)	= Zone selectivity output for S protection or output in "forward" direction for D protection
TI/L1-L2-L3	= Current transformer phase L1-L2-L3
TI/N	= Current transformer on neutral
TU1-2	= Insulation voltage transformer (outside circuit-breaker)
Uaux	= Auxiliary supply voltage
UI/L1-L2-L3	= Current sensor phase L1-L2-L3
UI/N	= Current sensor on neutral
UI/O	= Single-pole current sensor
W2	= Serial interface with internal bus (local bus)
W9...14	= RJ45 connector for communication modules
W9R...12R	= RJ45 connector for redundant communication modules
X	= Delivery connector for auxiliary circuits of withdrawable circuit-breaker
XB1...7	= Connectors for circuit-breaker applications
XF	= Delivery terminal box for position contacts of withdrawable circuit-breaker
XK1...3	= Connectors for auxiliary circuits of EKIP protection release
XK7	= Connector for auxiliary circuits of communication modules
XV	= Delivery terminal board for auxiliary circuits of fixed circuit-breaker
YC	= Closing coil
YO	= Opening coil
YO1	= Opening coil for overcurrent
YO2	= Second opening coil
YR	= Coil for electrical resetting of trip contact S51
YU	= Undervoltage coil

Notes XT7-XT7M


- A) Auxiliary power supply must be present for zone selectivity and local bus functions (consult Fig. 31-32).
- B) When there are mixed auxiliary contacts, 01 and 02 are 400V, while 03-04 are 24V.
- C) Always supplied with Ekip Com module.
- D) Always supplied with motor for loading closing springs in Fig. 13.
- E) A voltage transformer is mandatory in the case of external sockets. External sockets are mandatory for systems for over 690V rated voltage. Admissible maximum rated secondary voltage is 230V.
- F) Connections between RC residual current protection sensor and poles of connector X (or XV) of the circuit-breaker must be made of 4-pole shielded cable with paired braided conductors (BELDEN 9696 paired type or equivalent) no more than 10 m in length.
- G) Earth fault protection (Gext) by means of a current sensor on the neutral point of the MV/LV transformer is available with all electronic protection releases equipped with display interface with LSIG protections. The connection between terminals 1 and 2 of the UI/O current transformer and Ge+ and Ge- poles of connector X (or XV) must be made of shielded and stranded 2-pole cable (BELDEN 8841 or equivalent) no more than 15 m in length.
- H) Use the supplied cable to make the connection. There must be no break in the cable. Use of other cables or extensions using intermediate terminal boxes is not allowed. With a circuit-breaker, poles Ne+ and Ne- of connector X (or XV) are short-circuited unless the external neutral is present: enable short-circuit if connection is absent.
- I) Mandatory if any Ekip module is present.
- L) Up to two applications between Fig. 41...59 taken only once can be supplied. The Ekip Com module selected can be duplicated by choosing between Fig. 61...67.

Reading information


Information on how to read the diagrams

- M) Opening and closing commands from Ekip Actuator can be obtained with Y0 and Y0 coils, with 110-120VDC and 240-250VAC maximum voltage values.
- N) Use BELDEN 3105A cables or equivalent.
- O) Contact 8751/5 should be connected once only to a single module when there are several Ekip Com modules with withdrawable circuit-breakers.
- P) Auxiliary voltage Uaux. Enables all the functions of the EKIP electronic protection releases to be activated. "Galvanically separated convertors" conforming to standard IEC 60950 (UL 1950) or equivalent must be used since an earthed Uaux is required.
- Q) Use BELDEN 3105A cables or equivalent not more than 15m in length.
- R) Recommended RJ45 cable: CAT6 STP.
- S) Consult "Technical Application Papers - vol. 9: Bus Communication with ABB Circuit-breakers" for serial line connection EIA RS485.
- T) Short-circuit terminals 1200 on if a terminating resistor must be connected to the Local Bus.
- U) Use Belden 3079A cables or equivalent. For further details see White Paper 1SDCOO741200201 "Communication with SACE Emax 2 Circuit- Breakers".
- V) Use Belden 3084A cables or equivalent. For further details see White Paper 18DCOO7412G0201 "Communication with SACE Emax 2 Circuit- Breakers".
- W) Contacts S4/1 and S4/2 in Fig. 17 can be used to open the undervoltage coil circuit shown in Fig. 73-74 when the circuit-breaker is open and to close it again in the presence of a closing command, in compliance with the Standard governing machine tools.
- X) Contact S52 signals the state of the Y02 / YU opening coils.
For coil Y02, the contact connected to poles 25-28 of connector X (or XV) is closed with Y02 energized (circuit-breaker opening activated), contact 25-26 is closed with Y02 de-energized.
For coil YU, the contact connected to poles 25-28 of connector X (or XV) is closed with YU de-energized (circuit-breaker opening activated), contact 25-26 is closed with YU energized.
- Z) Ekip Supply cannot be used for direct supply to the electronic release by means of terminals K1 and K2.
- AA) See Fig. 31 and 32 for connection of W3 and W4.
- AB) Use BELDEN 8762/8722 two-pole shielded cable or equivalent. The shield must be earthed on the selectivity input side (for zone selectivity) or on both sides (for other applications).
- AC) Admissible maximum rated secondary voltage is 120V.
- AD) Use PENTRONIC TEC/SITW-24F (type TX) insulated cables for thermocouples or equivalent, no more than 1'm in length.
- AE) Use appropriate cables compatible with the workplace in which the 4-20mA current sensor is used and not more than 3 m in length.


Wiring diagrams




Three-pole or four-pole circuit-breaker with thermal magnetic trip unit



Three-pole circuit-breaker with magnetic trip unit




Three-pole or four-pole switch-disconnector




Three-pole or four-pole version circuit-breaker with Ekip Dip trip unit


Wiring diagrams




Three-pole or four-pole version circuit-breaker
XT5-XT6 with Ekip Touch trip unit




Three-pole or four-pole version circuit-breaker
with thermal magnetic trip unit and residual
current device




Three-pole or four-pole version circuit-breaker
with Ekip Dip trip unit and residual current device




Three-pole or four-pole version circuit-breaker
with Ekip Touch trip unit and residual current
device




Four-pole circuit-breaker with thermal magnetic trip unit and RC Sel 200 or RC B type residual current release




Four-pole circuit-breaker with thermal magnetic trip unit and RC Sel residual current release




Four-pole circuit-breaker with electronic trip unit and RC Sel residual current release



Three-pole fixed version circuit-breaker with Ekip Dip trip unit with current transformer on the neutral conductor outside the circuit-breaker




Three-pole or four-pole XT4 circuit-breaker with Ekip E-LSIG microprocessor based release




Fixed version three-pole XT4 circuit-breaker with Ekip E-LSIG with current transformer on neutral conductor, external to circuit-breaker

Wiring diagrams



Three-pole fixed version circuit-breaker with Ekip Touch trip unit with current sensor on the neutral conductor outside the circuit-breaker



Three-pole fixed version circuit-breaker with Ekip Touch trip unit with current and voltage sensor on the neutral conductor outside the circuit-breaker





Diagram recommended for three-pole plug-in or withdrawable version circuit-breakers with Ekip Dip trip unit with current sensor on the neutral conductor outside the circuit-breaker




Recommended diagram for plug-in or withdrawable version three-pole circuit-breakers with Ekip Dip trip unit, current transformer and voltage connection on neutral conductor, external to circuit-breaker

Wiring diagrams

Diagrams for XT1...XT4


- 1) Shunt opening release.**
- 2) Supplementary shunt opening release (only for four-pole circuit-breakers).**
- 4) Supplementary permanent shunt opening release (only for four-pole circuit-breakers).**
- 5) Instantaneous undervoltage release (see Notes B and F).**
- 6) Undervoltage release with electronic time delay device outside the circuit-breaker, see note B).**



Wiring diagrams


Diagrams for XT1...XT4

- 7) Instantaneous undervoltage release in the version for machine tools with one contact in series (see notes B, C and F).
- 8) Instantaneous undervoltage release in the version for machine tools with two contacts in series (see Notes B, C and F).
- 9) First auxiliary early contact operated by the crank handle.
- 10) Second auxiliary early contact operated by the crank handle.
- 11) One changeover contact for electrical signaling of circuit-breaker open due to tripping of the residual current release type RC Inst, RC Sel, RC B Type or RC Sel 200.
- 12) Residual current release circuits type RC Sel, RC B Type or RC Sel 200.
- 13) Two contacts for electrical signaling of residual current release pre-alarm and alarm type RC Sel, RC B Type or RC Sel 200.



Motor operator

- 21) Direct control motor operator (MOD) (only for XT1 and XT3 fixed or plug-in circuit-breakers) (see note 1).
- 22) Motor operator with stored energy (MOE) (only for circuit-breakers XT2 and XT4).
- 23) A contact for electrical signaling of stored energy motor operator that can be operated remotely.




Wiring diagrams

Diagrams for XT1...XT4


Signaling contacts

- 31) One changeover contact for electrical signaling of circuit-breaker open or closed and one changeover contact for electrical signaling of circuit-breaker open due to tripping of the magnetic, thermal magnetic or electronic trip units, YO, YO1, YO2, YU (trippped position) (only for voltages up to 250V) (see notes E and I).
- 32) Two changeover contacts for electrical signaling of circuit-breaker open or closed, two change over contacts for electrical signaling of circuit-breaker open due to tripping of the magnetic, thermal magnetic or electronic trip units, YO, YO1, YO2, YU (trippped position) and one changeover contact for electrical signaling of circuit-breaker open due to tripping of the ther momagnetic or electronic trip unit (only for voltages up to 250V).
- 33) Three changeover contacts for electrical signaling of circuit-breaker open or closed and two changeover contacts for electrical signaling of circuit-breaker open due to tripping of the magnetic, thermal magnetic or electronic trip units, YO, YO1, YO2, YU (trippped position) (only for voltages up to 250V).



Signaling contacts


- 34) Three changeover contacts for electrical signaling of circuit-breaker open and one changeover contact for electrical signaling of circuit-breaker open due to tripping of the magnetic, thermal-magnetic or electronic trip units, YO, YO1, YO2, YU (trippped position) (only for voltages up to 250V).
 - 35) One changeover contact for electrical signaling of circuit-breaker open due to tripping of the thermal magnetic electronic trip unit (only for voltages up to 250V).
 - 36) Two changeover contacts for electrical signaling of circuit-breaker open or closed and one changeover contact for electrical signaling of circuit-breaker open due to tripping of the magnetic, thermal magnetic or electronic trip units, YO, YO1, YO2, YU (trippped position) (only for voltages up to 250V).
 - 37) One changeover contact for electrical signaling of circuit-breaker open or closed and one changeover contact for electrical signaling of circuit-breaker open due to tripping of the magnetic, thermal magnetic or electronic trip units, YO, YO1, YO2, YU (trippped position) (only for voltage up to 400V).
 - 38) Two changeover contacts for electrical signaling of circuit-breaker open or closed (only for voltage up to 400V).



Wiring diagrams


Diagrams for XT1...XT4

- 39) Three supplementary changeover contacts for electrical signaling of circuit-breaker open or closed (only for fixed or plug-in version circuit-breakers).**
- 41) First changeover position contact of the circuit-breaker, for electrical signaling of connected (only for plug-in or withdrawable version circuit-breakers).**
- 42) Second changeover position contact of the circuit-breaker, for electrical signaling of connected (only for plug-in or withdrawable version circuit-breakers).**
- 43) Third changeover position contact of the circuit-breaker, for electrical signaling of connected (only for plug-in or withdrawable version circuit-breakers).**
- 44) Fourth changeover position contact of the circuit-breaker, for electrical signaling of connected (only for plug-in or withdrawable version circuit-breakers).**
- 45) First changeover position contact of the circuit-breaker, for electrical signaling of isolated (only for withdrawable version circuit-breakers).**
- 46) Second changeover position contact of the circuit-breaker, for electrical signaling of isolated (only for withdrawable version circuit-breakers).**
- 48) Auxiliary circuits of the 24V auxiliary power supply unit and of the HMI030 type interface unit (see note E).**



Signaling contacts

142) Auxiliary circuits of Ekip Com or Kit of 24V DC auxiliary voltage for electronic trip units and of Ekip Multimeter display.





Wiring diagrams

Diagrams for XT1...XT4

Electronic trip unit Touch/Hi-Touch with connections through Slim Micro I/O

Ekip Touch/Hi-Touch with Slim Micro I/O




Ekip Touch/Hi-Touch with Slim Micro I/O and Ekip Multimeter

Wiring diagrams


Diagrams for XT1...XT4

Ekip Touch/Hi-Touch with Slim Micro I/O, Ekip Cartridge and Ekip Multimeter



Electronic trip unit Ekip E-LSIG connected with Ekip Display or Ekip LED Meter

50) Auxiliary circuits of the Ekip E-LSIG microprocessor-based release connected to the Ekip Display (display) or Ekip LED Meter (current display) display unit.




Wiring diagrams

Diagrams for XT1...XT4


Electronic trip unit Ekip LSI, Ekip LSIG, Ekip M-LRIU connected with Ekip Display or Ekip LED Meter

51) Auxiliary circuits of the electronic trip unit type Ekip LSI, Ekip LSIG or Ekip MLRIU connected to display unit type Ekip Display (display) or Ekip LED Meter (current display).



Auxiliary circuit of Ekip-Com and HMI030

52) Auxiliary circuits of the Ekip Com type interface unit and of the HMI030 type interface unit (see note E).




Wiring diagrams

Diagrams for XT1...XT4

Electronic trip unit Ekip LSI, Ekip LSIG or Ekip M-LRIU connected to interface unit Ekip Com and with actuator unit type MOE-E for the stored energy motor operator


- 23) One Contact for electrical signaling of stored energy motor operator that can be operated remotely.**
53) Auxiliary circuits of the electronic trip unit type Ekip LSI, Ekip LSIG or Ekip M-LRIU connected to interface unit type Ekip Com and with actuator unit type MOE-E for the stored energy motor operator.



Auxiliary circuits of the electronic trip unit Ekip M-LRIU connected to the contactor control unit for starting the motor PR212/CI (the circuit to the motor thermistor is optional)

54) Auxiliary circuits of the electronic trip unit type Ekip M-LRIU connected to the contactor control unit for starting the motor type PR212/CI (the circuit to the motor thermistor is optional).

62) Motor thermistor circuit.




Wiring diagrams

Diagrams for XT1...XT4

Electronic trip unit Ekip M-LRIU connected to the contactor control unit for starting the motor PR212/CI and with ABB AF series contactor (the circuit to the motor thermistor is optional)

55) Auxiliary circuits of the electronic trip unit type Ekip M-LRIU connected to the contactor control unit for starting the motor type PR212/CI and with ABB AF series contactor (the circuit to the motor thermistor is optional).

62) Motor thermistor circuit.



Instructions for resetting the circuit-breaker after tripping

Selection of the type of circuit-breaker resetting depends on design requirements and on service conditions.

Resetting can take place following tripping of the following releases:

- overcurrent;
- undervoltage;
- shunt opening.

The following three possibilities are suggested (see diagrams in the following page):

1. Only manual resetting

To be wired (by the customer): contact SO1, contact SY/1 and the auxiliary relay KO (only for MOD).

Opening is prevented until the circuit-breaker is in the tripped position.

To reset the circuit-breaker it is necessary to activate the special lever on the front of the motor until the circuit-breaker goes into the open position.

2. Electrical resetting under the operator's responsibility

To be wired (by the customer): contact SO1, SO2, contact SY/1 and the auxiliary relay KO (only for MOD).

Opening of the circuit-breaker is allowed by means of the contact SO2. Such contact shall be protected to avoid unwanted activation and can be used only if the information received by the operator make it possible to exclude tripping due to a short-circuit, or if the causes of the short-circuit have been removed.

3. Electrical resetting always allowed

To be wired (by the customer): contact SO1, SO2, contact SY/1 and the auxiliary relay KO (only for MOD).


Opening is always allowed by means of contact SO2.

NB: If the magnetic, thermal magnetic or electronic trip unit is present, it is necessary to find the causes which led to the circuit-breaker being in the tripped position so as to prevent reclosing under short-circuit conditions. In all cases, manual resetting is always allowed.


Wiring diagrams

Diagrams for XT1...XT4


MOD



MOE or MOE-E




57) Interface unit type Ekip Com with direct supply to the trip unit and MOE-E motor operator



Wiring diagrams


Diagrams for XT1...XT4

54) Stand-alone interface unit type Ekip Com with MOE-E motor operator



- 61) Modbus RTU STA interface of Ekip Com Unit to be installed inside the circuit-breaker
 62) Modbus RTU interface of Ekip Com Unit to be installed inside the circuit-breaker
 63) Modbus TCP STA interface of Ekip Com Unit to be installed inside the circuit-breaker
 64) Modbus TCP interface of Ekip Com Unit to be installed inside the circuit-breaker
 65) Profinet interface of Ekip Com Unit to be installed inside the circuit-breaker
 66) Ethernet IP interface of Ekip Com Unit to be installed inside the circuit-breaker
 67) IEC61850 interface of Ekip Com Unit to be installed inside the circuit-breaker
 68) Ekip Link interface of Ekip Com Unit to be installed inside the circuit-breaker
 69) ABB Ability™ Edge Industrial Gateway interface of Ekip Com Unit to be installed inside the circuit-breaker


—
 61 - 62 - 63 - 64 - 65 -
 66 - 67 - 68 - 69 as an
 alternative to each other




Wiring diagrams

Diagrams for XT1...XT4

131) Motor starting module Ekip CI




132) Motor starting module Ekip CI with ABB contactor series AF


Wiring diagrams


Diagrams for XT5 and XT6

- 1) Left opening coil - YO⁽¹⁾
- 2) Right opening coil - YO⁽¹⁾



(1) Up to 380-440V YO version

- 5) Instantaneous left undervoltage coil - YU⁽¹⁾
 6) Left undervoltage coil with electronic time-delay device outside the circuit-breaker - YU⁽²⁾
 7) Instantaneous left undervoltage coil in the version for machine tools with a contact in series - YU⁽³⁾



(1) Up to 380-440V YU version

(2) Up to 250V YU version


Wiring diagrams

Diagrams for XT5 and XT6

8) Instantaneous right undervoltage coil - YU⁽¹⁾

9) Right undervoltage coil with electronic time-delay device outside the circuit-breaker - YU⁽²⁾


10) Instantaneous right undervoltage coil in the version for machine tools with a contact in series - YU⁽¹⁾



(1) Up to 380-440V YU version

(2) Up to 250V YU version


15) Instantaneous undervoltage coil in the version for machine tools with two contact in series - YU



Wiring diagrams


Diagrams for XT5 and XT6

- 18) Open/closed circuit-breaker signalling contact and circuit-breaker tripped signalling contact (for voltage up to 250V)**
- 19) Open/closed circuit-breaker signalling contact and circuit-breaker tripped signalling contact (for voltage up to 250V) left position**
- 20) Signalling contact for minimum voltage relay tripping**



- 21) Three open/closed circuit-breaker signalling contacts and circuit-breaker tripped signalling contacts (for voltage up to 250V)**
- 22) Open/closed circuit-breaker 2 signalling contacts (for voltage up to 400V)**

* D)



Wiring diagrams


Diagrams for XT5 and XT6

23) Protection relay tripped signalling contact (for voltage up to 250V)

24) Two open/closed circuit-breaker signalling contacts and circuit-breaker tripped signalling contacts (for voltage up to 250V)


25) Open/closed circuit-breaker signalling contacts and circuit-breaker tripped signalling contacts (for voltage up to 400V)

* E)




- 28) Circuit-breaker test position signalling contacts**
29) Circuit-breaker disconnected position signalling contacts
30) Circuit-breaker inserted position signalling contacts
31) Circuit-breaker inserted position signalling contacts
32) Circuit-breaker inserted position signalling contacts

—
28 - 29
Only for withdrawable
version circuit-breaker



—
30 - 31 - 32
Only for plug-in or
withdrawable version
circuit-breaker




Wiring diagrams

Diagrams for XT5 and XT6


35) Differential relay tripped signalling contact S87/3

36) Differential relay circuits K87

37) Two contacts signalling differential relay pre-alarm and alarm S87




- 39) Auto/manual/lock status feedback**
40) Stored energy motor operator (MOE)




Wiring diagrams

Diagrams for XT5 and XT6

41) Direct auxiliary supply 24Vdc and local bus




42) Interface unit type Ekip Com




Wiring diagrams

Diagrams for XT5 and XT6

43) Stand alone interface unit type Ekip Com




39) Auto/manual/lock status feedback**44) Stand alone interface unit type Ekip Com with MOE-E motor operator**


Wiring diagrams

Diagrams for XT5 and XT6

39) Auto/manual/lock status feedback

45) Interface unit type Ekip Com with direct supply to relay and MOE-E motor operator





39) Auto/manual/lock status feedback**46) Interface unit type Ekip Micro Module I/O with MOE-E motor operator****73) Ekip Micro Module I/O**

Wiring diagrams

Diagrams for XT5 and XT6

50) Zone selectivity



- 61) Modbus RTU STA interface of Ekip Com unit**
62) Modbus RTU interface of Ekip Com unit
63) Modbus TCP STA interface of Ekip Com unit
64) Communication interface of Ekip Com unit (see table below)
65) Communication interface of Ekip Com unit (see table below)
66) Communication interface of Ekip Com unit (see table below)
67) Communication interface of Ekip Com unit (see table below)
68) Communication interface of Ekip Com unit (see table below)
69) Communication interface of Ekip Com unit (see table below)

—
61 - 62 - 63 - 64 - 65 -
66 - 67 - 68 - 69
As in alternative
to each other




FIG.	DESCRIZIONE / DESCRIPTION	BUS
64	MODBUS TCP	W9
65	PROFINET	W10
66	ETHERNET I/P™	W11
67	IEC61850	W12
68	LINK	W13
69	HUB	W14

Wiring diagrams


Diagrams for XT5 and XT6

71) Ekip signalling 1K


72) Ekip signalling maintenance module

94) Ekip CI

—
71 - 72
As in alternative
to each other




131) Motor starting module Ekip CI




Wiring diagrams

Diagrams for XT5 and XT6

132) Motor starting module Ekip CI with ABB contactor series AF




141) Ekip signalling 10K signalling unit




Wiring diagrams

Diagrams for XT5 and XT6

142) Ekip Multimeter unit with relay and direct auxiliary supply 24Vdc




143) Ekip Multimeter unit with relay and auxiliary supply through module 110-240Vac/dc or 24-48Vdc




Wiring diagrams


Diagrams for XT7 and XT7 M



Three-pole or four-pole circuit-breaker with
Ekip Dip trip unit



Three-pole or four-pole circuit-breaker with
Ekip Touch trip unit




Three-pole or four-pole switch-disconnector



- 11a) Protection trip unit tripped signaling contact – S51**
12a) Contact for signaling position of loaded springs – S33M
13a) Motor for loading closing springs – M
14a) Trip contact reset coil – YR

—
12 - 13 - 14 only for XT7 M
circuit-breakers



Wiring diagrams


Diagrams for XT7 and XT7 M



16) Tripped position breaker signaling contact SY

17) Auxiliary early contacts – S4

—
16 - 17 only for XT7
circuit-breakers






24) RC residual current sensor input (ANSI 64&50N TD)

24a) RC differential ground fault protection sensor input (ANSI 87N)

24 - 24a as an alternative to each other and to figure 25



Wiring diagrams


Diagrams for XT7 and XT7 M



25) Transformer star centre sensor input

27) Current sensor input on external neutral (only for 3-pole circuit breaker)

25 as an alternative
to figures 24 - 24a





70) YO2/YU opening coil state signaling contact – S52

71) Ready to close contact – RTC

72) Second opening coil – YO2


73) Undervoltage coil – YU

73) Undervoltage coil with external time-lag device YU, D

—
70 only for XT7
circuit-breakers

71 only for XT7 M
circuit-breakers

72 - 73 - 74 as an
alternative to each other



Wiring diagrams

Diagrams for XT7 and XT7 M



75) First opening coil – YO

76) First opening coil with control from protection trip unit – YO, Ekip Com Actuator


77) First closing coil – YC

78) First opening coil with control from protection trip unit – YC, Ekip Com Actuator

—
75 - 76 as an alternative
to each other

77 - 78 only for XT7 M
circuit-breakers


77 - 78 as an alternative
to each other





81) Open/Close auxiliary contacts of the circuit-breaker (first set)

91a) Supplementary open/close auxiliary contacts outside the circuit-breaker




Wiring diagrams

Diagrams for XT7 and XT7 M


95a) Contacts for signaling of circuit-breaker in racked-in, test, racked-out position

—
only for withdrawable
version



Wiring diagrams


XT2-XT4-XT5-XT7-XT7 M modules



75) Ekip Cartridge for one module and one Ekip Supply

76) Ekip Cartridge for three modules and one Ekip Supply

—
75 - 76 as an alternative
to each other



Wiring diagrams

XT2-XT4-XT5-XT7-XT7 M modules

Installation slot

For XT2-XT4-XT5 Ekip Cartiridge

Ekip Supply	Module




Ekip Supply	Module	Module	Module


For XT7-X7M terminal box



81a) Ekip Supply: auxiliary supply through module 110-240Vac/dc or 24/48Vdc and local bus

—
81 as an alternative
to figure 49




83) Ekip Signalling 2K-1**84) Ekip Signalling 2K-2**


Wiring diagrams

XT2-XT4-XT5-XT7-XT7 M modules

85) Ekip Signalling 2K-3

86) Ekip Synchrocheck




87) Ekip Signalling 3T-1**88) Ekip Signalling 3T-2**

Wiring diagrams

XT2-XT4-XT5-XT7-XT7 M modules


XT2-XT4-XT7-XT7 M

- 89) Ekip Com Modbus RTU
- 90) Ekip Com Modbus TCP
- 92) Ekip Com Ethernet/IP
- 94) Ekip Com IEC61850
- 95) Ekip Link
- 96) ABB Ability™ Edge Industrial Gateway
- 97) Ekip Com Profinet
- 91) Ekip Com Profibus DP
- 93) Ekip Com DeviceNet



XT5

- 85) Ekip Com Modbus RTU**
- 86) Ekip Com Modbus TCP**
- 87) Ekip Com Profinet**
- 88) Ekip Com I/P™**
- 89) Ekip Com IEC61850**
- 90) Ekip Com Link**
- 91) ABB Ability™ Edge Industrial Gateway**
- 92) Ekip Com Profibus DP**
- 93) Ekip Com DeviceNet™**





Wiring diagrams

XT2-XT4-XT5-XT7-XT7 M modules

Installation slot

For XT2-XT4-XT5 Ekip Cartiridge



For XT7-X7M terminal box



110) Ekip Com Modbus RTU redundant

111) Ekip Com Modbus TCP redundant


113) Ekip Com Profinet redundant

115) Ekip Com Ethernet IP redundant

116) Ekip Com IEC61850 redundant

112) Ekip Com Profibus DP redundant

114) Ekip Com Devicenet™ redundant





—
ABB SACE S.p.A.
Electrification Business Area
Smart Power Division
5, Via Pescaria
I-24123 Bergamo - Italy
Phone: +39 035 395.111

new.abb.com/low-voltage/products/circuit-breakers/xt



Stay tuned. Discover more by visiting the webpage reserved to SACE Tmax XT and be always up-to-date with the latest edition of the catalogue.